This is the Post-print version of the following article: *Litza Halla Velazquez-Jimenez, Esmeralda Vences-Alvarez, Jose Luis Flores-Arciniega, Horacio Flores-Zuñiga, Jose Rene Rangel-Mendez, Water defluoridation with special emphasis on adsorbents-containing metal oxides and/or hydroxides: A review, Separation and Purification Technology, Volume 150, 2015, Pages 292-307,* which has been published in final form at: <u>https://doi.org/10.1016/j.seppur.2015.07.006</u>

© 2015. This manuscript version is made available under the Creative Commons Attribution-NonCommercial-NoDerivatives 4.0 International (CC BY-NC-ND 4.0) license <u>http://creativecommons.org/licenses/by-nc-nd/4.0/</u>

Accepted Manuscript

Water defluoridation with special emphasis on adsorbents-containing metal oxides and/or hydroxides: a review

Velazquez-Jimenez Litza Halla, Vences-Alvarez Esmeralda, Flores-Arciniega Jose Luis, Flores-Zuñiga Horacio, Rangel-Mendez Jose Rene

PII:	\$1383-5866(15)30077-0
DOI:	http://dx.doi.org/10.1016/j.seppur.2015.07.006
Reference:	SEPPUR 12422
To appear in:	Separation and Purification Technology
Received Date:	6 March 2015
Revised Date:	26 June 2015
Accepted Date:	5 July 2015



Please cite this article as: V.L. Halla, V-A. Esmeralda, F.J. Luis, F-Z. Horacio, R.J. Rene, Water defluoridation with special emphasis on adsorbents-containing metal oxides and/or hydroxides: a review, *Separation and Purification Technology* (2015), doi: http://dx.doi.org/10.1016/j.seppur.2015.07.006

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.

Water defluoridation with special emphasis on adsorbents-containing metal oxides and/or hydroxides: a review

Velazquez-Jimenez Litza Halla^a, Vences-Alvarez Esmeralda^a, Flores-Arciniega Jose Luis^b, Flores-Zuñiga Horacio^b, Rangel-Mendez Jose Rene^a*
 6

 ^aDivision of Environmental Sciences and ^bDivision of Advanced Materials; Instituto Potosino de Investigación Científica y Tecnológica, A.C., Camino a la Presa San José 2055, Col. Lomas 4a sección, C.P. 78216, San Luis Potosí, S.L.P., México.

10

3

11 Abstract

12

13 Fluoride contamination in drinking water has been recognized as one of the major worldwide 14 problems since this represents a serious threat to human health. The World Health Organization (WHO) recommends the guideline value (maximum permissible limit) of 1.5 mg L^{-1} for fluoride in drinking water. 15 16 Unfortunately, many countries have high fluoride concentrations (up to 30 mg L^{-1}) in water supplies that 17 may cause widespread fluorosis and skeletal illnesses among the population. Many methods have been 18 developed for fluoride removal from water including adsorption, ion exchange, electrodialysis and 19 precipitation. Nevertheless, more efficient and cost-effective processes and materials are needed to 20 comply with the fluoride maximum permissible limit. Adsorption has been widely used because it is the 21 most cost-effective methodology for the removal of ionic contaminants from aqueous solutions. Various 22 adsorbent materials have been used to remove fluoride from water, for instance activated alumina, activated carbon, bone char, minerals, among others, but unfortunately their chemical stability and/or 23 24 selectivity and adsorption capacity is something that still has to improve substantially. During the last 25 decade, metal oxyhydroxides in powder form and supported on different matrixes have been of great 26 interest for fluoride removal. This review condenses the advances on this last topic that is still under study.

27

28 Key words: fluoride, adsorption, metal oxyhydroxides, water treatment.

29

30 1. Introduction

Fluoride source occurs in a geological environment. Minerals like sellaite (MgF₂), fluorspar (CaF₂), cryolite (Na₃AlF₆) and fluorapatite [$3Ca_3(PO_4)_2Ca(F,Cl_2)$] can release fluoride ions (F⁻) when the conditions of temperature, pH, anion-exchange, among others, favor their dissolution [1]. The occurrence of F⁻ in groundwater is also due to the anthropogenic discharges from commercial and/or domestic activities, and from industry (i.e. semiconductor manufacturing, glass and ceramic production, uranium and aluminum refinement, toothpaste, fertilizer, electroplating, etc.).

37

41

At present, groundwater is the primary source of drinking water for roughly 30 percent of the world's 38 population and is often the main source of fluoride intake by humans in areas where fluorosis is endemic 39 [2]. The relationship of fluoride-human health is quite extensive, and is focused on the adverse effects on 40 teeth and bones (dental and skeletal fluorosis), DNA structure (genetic mutations, birth defects), and illnesses spread (cancer, Alzheimer disease, renal and neurological damage), among others [3].

Fluoride is considered beneficial at levels around of 0.7 mg L^{-1} but it is hazardous if it exceeds 1.5 42 mg L⁻¹, which is the World Health Organization (WHO) limit in drinking water and this is followed in 43 most nations. High fluoride concentrations in groundwater, up to 30 mg L^{-1} , can be found in many parts of 44 45 the world, and is endemic in at least 25 countries across the globe [4-6]. The most affected areas are parts 46 of China, India, Sri Lanka, South Africa, and in less proportion in rural and semi-urban areas of United States of America, central Europe, northern Mexico and central Argentina. This problem is exacerbated by 47 the need to drink more water because of the heat and dry climates, and the limited water resources in 48 49 Third World countries. Even in developed nations, fluoride removal (or defluoridation) from public 50 drinking water supplies has been a contentious issue that ends in more stringent fluoride limits [7]. Efforts 51 to reduce fluoride from drinking water to acceptable limits are essential, which require a great deal of 52 investment in research. There are several methods and techniques that can be employed for water 53 defluoridation (precipitation/coagulation, ion-exchange, membrane technique, etc.), and its choice 54 depends on the fluoride ions concentration, existing treatment processes, treatment costs, handling of 55 residuals and versatility of the given technique [8]. However, these methods have some limitations like performance, production of waste, and high costs of installation. Adsorption has shown to be a better 56 57 choice to remove pollutants from water, such as fluoride ions, because of its lower cost, flexibility and simplicity of design, high efficiency, and high selectivity [9]. A variety of adsorbent materials have been 58 59 used to remove fluoride from water, such as carbon based adsorbents, agricultural and industrial wastes, 60 metallic oxides and hydroxides or oxihydroxides [8-13]. Nevertheless, recent developments have 61 discovered that metals, in their form of oxides or oxyhydroxides, by their selves or loaded in several 62 materials are good candidates to remove fluoride from water. Unfortunately, this knowledge is dispersed 63 in the literature, hence, the aim of this review is to condense the most relevant studies on fluoride removal 64 from water by adsorption, emphasizing the novel metal oxide/oxyhydroxides adsorbent materials.

65

2. Technologies for fluoride removal from water 66

67 Several techniques have been developed in order to decrease the fluoride concentration to safe limits in water supplies. Defluoridation methods, based on the nature of the type of process involved, can be 68 69 generally grouped into precipitation/coagulation, adsorption and/or ion exchange, and filtration by 70 membranes. The principle involved in precipitation-coagulation technology is that the fluoride ions adsorb

on the flocs and are then subsequently removed either simultaneous or in succeeding treatment units such as sedimentation, fixed beds or microfiltration units. On the other hand, adsorption is characterized by the use of adsorbents where fluoride is concentrated and removed from water. Parameters such as pH, temperature, and interfering anions have been considered in this research topic since they can greatly affect the adsorption process [10]. The adsorbent materials include activated carbon, activated alumina, ion-exchange resins, fly ash, clay, minerals, soils, among others [11]. On the other hand, membrane techniques involve the use of semi-permeable membranes that are briefly discussed in section 2.2.

78 2.1 Precipitation/coagulation

79 Coagulation with aluminum salts has been employed for a long time to remove fluoride ions [12, 80 13]. Coprecipitation or adsorption may occur when Al(III) ions are added to fluoride-containing water. 81 The efficiency of the removal of fluoride by a fixed amount of aluminum salt depends on pH, alkalinity, 82 the coexisting anions, and other solution characteristics [14]. The most appropriate pH for defluoridation 83 using the coagulation technique is 5.5–6.5 [15]. Nalgonda technique, is one of the most popular 84 defluoridation methods in countries like India, Kenya, Tanzania and Senegal, it involves the addition of 85 calculated quantities of alum, lime and bleaching powder to the water. After the mixing, the water is processed with flocculation, sedimentation, filtration and disinfection [11]. Nevertheless, this technique 86 presents several disadvantages like a high concentration of SO_4^{2-1} ions and residual aluminum levels in the 87 88 treated water.

89 On the other hand, the electrocoagulation (EC) process utilizes "sacrificed" anodes to form an 90 active coagulant which is used to remove the pollutant by precipitation and flotation *in situ*. Compared 91 with traditional chemical coagulation (CC), the electrocoagulation process requires less space and does 92 not require chemical storage, dilution, and pH adjustment [16]. It is proven to be effective in water 93 treatment system for small or medium size communities [17].

94 Although many studies have investigated the removal of fluoride by aluminum (Al) coagulation, 95 few studies have been focused on the effects of colloids, such as kaolin suspensions. Lui et al., [18] 96 studied the effects of fluoride at different molar ratios of fluoride to Al (R_{F:Al}) on turbidity removal, zeta 97 potential, flocs growth, and residual Al levels in a series of batch experiments. The authors found that at insufficient Al doses, the fluoride showed adverse effects at R_{F:Al} above 10:10, whereas the opposite effect 98 99 was observed at R_{F:Al} below 2:10 at pH<8. At pH greater than 8, little effect was observed over a wide 100 R_{F:Al} range of 1:10 to 30:30. The adverse effects of fluoride were related to the decrease of zeta potential, 101 smaller flocs and elevated levels of Al residual. Moreover, this study indicated that after adsorbing 102 fluoride, the freshly-prepared aluminum hydroxides (*in-situ* $Al_2O_3 \cdot H_2O$) that were spent may be reclaimed 103 as coagulant for colloid removal after being dissolved by an acid solution. Some other researchers such as 104 Hu et al., [19] studied the effect of the molar ratio of hydroxide and fluoride ions (γ -OH and γ F) with

respect to Al(III) ions in coagulation and electrocoagulation (EC). This study showed that the efficiency of defluoridation was approximately 100% when the sum of γ -OH and γ F (γ -OH+F) was close to 3. This finding reveals that fluoride and –OH ions can co-precipitate with Al(III) ions and develop Al_nF_m(OH)_{3n-m}.

108 Also, Sujana et al., [20] studied the removal of fluoride from aqueous solution by using aluminum 109 sludge. This study considered the contact time, the adsorbent and adsorbate concentration, temperature, 110 pH, and the effect of the concentrations of other anions. The treated alum showed a heterogeneous surface 111 in nature which was reflected in the heterogeneous binding sites. The optimum pH for complete removal 112 of fluoride ions was 6, the adsorption rate was faster during the initial 5 minutes and the equilibrium was 113 reached within 240 minutes. The adsorption process followed a first-order kinetics and could be affected 114 with an increase in temperature from 307 to 337 K, besides, defluoridation in the presence of phosphate and silicate at 10-50 mg L^{-1} has an adverse effect on the fluoride removal. Furthermore, Zhu et al., [21] 115 used a new approach to investigate fluoride distribution in the defluoridation process by 116 117 electrocoagulation, which was divided into three parts: remained in water, removal by electrodes, and 118 adsorption on hydroxide aluminum flocs. The fluoride distribution was investigated in terms of various 119 critical parameters such as pH, charge loading, current density and the initial concentration of fluoride. 120 The results demonstrated that defluoridation can be performed with high efficiency between pH 6.0-7.0, 121 and would become dominant even under basic conditions (pH>7.5). The optimal charge loading and current density were established at 4.15 Faradays m⁻³ and 9.26 Amperes m⁻², respectively. The general 122 relation between the overall defluoridation efficiency and initial F⁻ concentration decreased from 92 to 123 80% while the range increased from 3 to 15 mg L⁻¹. A chemical complex of $Al_n(OH)_m F_k^{3n-m-k}$ was 124 125 formulated to explain the mechanism inside the EC defluoridation process. Following with the 126 electrocoagulation process, Hu et al., [22] developed a variable order kinetic (VOK) model derived from 127 the Langmuir equation to simulate the fluoride removal kinetics by electrocoagulation with bipolar 128 aluminum electrodes. The results showed that parameters Γ_{max} and k for the VOK model were constant 129 when the initial fluoride concentration varied. On the other hand, they observed that the current efficiency 130 is independent upon initial fluoride concentration but this varies with current density. Therefore, their 131 results revealed good agreement between the predictive equation and the experimental data. However, 132 they found limitations in the VOK model since this could not simulate systems with an initial acidity of 133 0.5 or 1.0 mM and with a high initial fluoride concentration.

Moreover, Gong et al., [23] studied the effects of aluminum fluoride complexes by a series of batch experiments. The transformation of the fluoride species in coagulation was studied by a simultaneous determination of free fluoride and total fluoride at different pH and fluoride concentrations. For total fluoride removal, the optimal pH was 7.0, and up to this value complexes were completely dissociated to free fluoride. Comparison between coagulation with complexation and adsorption by Al(OH)₃ flocs

demonstrated that coagulation shows higher fluoride removal efficiency between pH 6.0 and 9.0, and the process of coagulation involved an Al-F complexation, an Al hydrolysis and a precipitation. During the adsorption process, the fluoride was removed by an ion exchange with –OH. Besides, it was implied that l-F complexation promotes fluoride removal in coagulation. Furthermore, the characterization by FTIR and XPS also showed that Al-F-OH co-precipitates in coagulation.

144

145 2.2 Membrane Processes

146 Membrane processes imply the use of a semi-permeable membrane as an interphase between adjacent 147 phases, and acts as a barrier controlling material transport between them. The driving force to transport in 148 membrane separation is generally a difference in chemical potential created due to a concentration or 149 pressure gradient across the membrane, or by an electric field. Two important phenomena that 150 significantly reduce membrane permeability and selectivity are concentration polarization and membrane 151 fouling. Membrane techniques like reverse osmosis, nanofiltration, dialysis and electrodialysis have been 152 applied industrially in fields ranging from medicine to the chemical industries in the removal of inorganic 153 ions, being one of them fluoride [24]. The use of these techniques can be very attractive for water 154 treatment processes to avoid some difficulties that precipitation, coagulation and adsorption may present 155 during their use.

156

157 2.2.1 Reverse osmosis

158 Reverse osmosis produces extremely pure water. This is a physical process in which contaminants are 159 removed by applying higher pressure on the feedwater to direct it through a semipermeable membrane 160 (see Figure 1). The process is the reverse of natural osmosis as a result of the applied pressure to the 161 concentrated side. The current applications are in desalination of drinking water and water purification for 162 microelectronics and medical uses, because it rejects all dissolved solids. The factors that usually 163 influence the membrane selection are the cost, recovery, rejection, water characteristics to treat, 164 temperature, and pressure, among others. Defluoridation using reverse osmosis systems is running 165 successfully in many developed countries [24].

Arora et al., [25] evaluated the potential of a reverse osmosis membrane for fluoride removal of underground water samples from India, at concentrations between 2.5 to 10 mg L⁻¹. The results indicated that reverse osmosis membranes removed up to 95% of F⁻, and there was no need to remineralize the water. Besides, at pH >7 the efficiency decreased, but in acidic pH the performance of the membrane was affected and needed to be replaced, on the other hand, Ndiaye et al., [26] studied fluoride removal from effluents of the electronic industry using reverse osmosis. The results showed that the rejection of fluoride was typically higher than 98%, considering that the membranes used in the study were fully regenerated

173 after each set of experiments. For industrial effluents, the process developed in this research allowed the reduction of the treated volume from 6 to 0.36 $\text{m}^3 \text{d}^{-1}$ without any pretreatment. Taking into account that 174 175 membranes are sensitive to the polarization phenomena, and that they tend to forward biological fouling 176 due to natural organic matter and microorganisms; mineral fouling can also occur when salts exceed and 177 tend to precipitate [24]. In this respect Nicolas et al., [27] optimized the softening pretreatment, by sodium 178 carbonate, of brackish water contaminated with high concentration of fluoride (> 5 mg L^{-1}) in order to 179 obtain purified water by reverse osmosis in a second stage: the calculated optimal amount of softening chemical was 15 mmol L⁻¹ of Na. Additionally, the pretreatment allowed not only an almost total removal 180 181 of calcium but also a partial elimination of magnesium and fluoride.

182 2.2.2 Dialysis and Electrodyalisis

183 Dialysis and electrodialysis are similar to reverse osmosis. In the case of dialysis, one or more solutes 184 are transferred from one solution, called the feed, to another solution called the dialysate, through a 185 membrane due to a concentration gradient. In electrodialysis, the separation of components of an ionic 186 solution occurs in a cell consisting of a series of anion and cation-exchange membranes. These are 187 arranged in an alternate manner between an anode and a cathode to form individual electro-dialysis cells. 188 During the process of electrodialysis, there is an increase in the ion concentration of one type in one type 189 of component and it is accompanied by a simultaneous decrease in the concentration of the other type of 190 component (see Figure 2) [28].

191 Hichour et al., [29] used contaminated water samples from Africa (Maghreb, Senegal), to study the 192 removal of fluoride with the Donnan dialysis process in a counter flow system. To maintain the fluoride 193 concentration below the acceptable values (1.5 mg L^{-1}) at the outlet of the feed compartment, the extracted fluoride ions were complexed by adding Al^{3+} into the receiver solution. Lounici et al., [30] also studied the 194 195 fluoride removal by using electrodialysis. Their results showed that desorption of fluoride from activated 196 alumina is a rapid process, within 6-15 min. Also, a study of adsorption-regeneration cycles showed that 197 the electrochemical technique was more efficient than commercial caustic soda with 95% of fluoride 198 removal. Following the same Donnan analysis, Germes et al., [31] also applied a hybrid process that 199 combines adsorption on aluminum (Al₂O₃) and zirconium oxide (ZrO₂) to treat groundwater with 4 mg L^{-1} 200 of fluoride concentration resulting from phosphate mining in Morocco. It was found that the fluoride 201 equilibrium concentration was attained more quickly and higher with ZrO₂ than with Al₂O₃. The 202 mineralization of the treated groundwater was not modified. The cation composition remained unchanged, 203 whereas anions (except chloride) were partially eliminated and substituted by Cl. The above lead to a 204 fluoride concentration below 1.5 mg L^{-1} .

An interesting study by Annouar et al., [32] reported the elimination of fluorides from underground water by adsorption on chitosan followed by electrodialysis with the help of CMX-ACS membranes. Both

207 methodologies approached a safe limit of fluoride concentration. Following the same route, Sahli et al., 208 [33] studied the defluoridation of brackish groundwater in Morocco by electrodialysis. This research group demonstrated that this methodology can defluorinate water with 3000 mg L^{-1} of total dissolved salts 209 and 3 mg L^{-1} of fluoride. Recently, Elazhar et al., [34] compared the performance of nanofiltration and 210 211 electrodialysis in fluoride removal from Moroccan groundwater. Although the performances are 212 comparable in both technologies, the study revealed that electrodialysis has the advantage of flexibility 213 with respect to the seasonal variation of fluoride content, and the final salt concentration can be adjusted. 214 Nevertheless, nanofiltration can be used for small-scale applications.

215

216 2.2.3 Nanofiltration

217 Nanofiltration is not often used in water treatment, but can compete with reverse osmosis and 218 electrodialysis for defluoridation of water supplies. The membranes that use this technology have 219 narrower pores than those used for reverse osmosis, and offer less resistance when the solutes pass 220 through them. As a consequence, the pressure required is much lower, less energy requirements, removal 221 of the solute is much less exhaustive, and flows are faster. Nanofiltration is generally used to remove divalent ions such SO_4^{2-} and Ca^{2+} , but it also can remove F⁻ from aqueous solutions despite being a very 222 small anion. Moreover, fluoride removal with this technique is possible due to its high charge density that 223 224 makes it a more strongly hydrated ion than others, and thus, it is more strongly retained in nanofiltration 225 membranes by steric effects. The selectivity of nanofiltration in comparison with reverse osmosis is also an advantage due to the low cost of membrane materials that contributes to its actual spread. Furthermore, 226 227 nanofiltration (as well as electrodialysis) is more suitable for producing drinking water directly without 228 the need of remineralization. The main difference between nanofiltration and electrodialysis is that the 229 second one requires regeneration of ion-exchange membranes thus making its use more expensive than 230 nanofiltration.

231 As reported by Mohapatra et al., [35], several studies have been carried out using nanofiltration for 232 demineralization of water, especially in the defluoridation of brackish water and wastewater treatment processes. Elazhar et al., [36] evaluated the use of nanofiltration to remove fluoride of 2400 m³ d⁻¹ of 233 234 water from a rural location in Morocco. The recovery rate obtained with this methodology was 84% of 235 water and a fluoride rejection of 97.8%. Recently, Nasr et al., [37] applied nanofiltration for defluoridation 236 of groundwaters. This study used commercial nanofiltration membranes and evaluated, among fluoride 237 removal, the influence of chloride, sulfate and calcium that usually co-exist in groundwater. The results 238 indicated that it is important to select an appropriate membrane in order to maintain Cl⁻ concentration in acceptable levels without losing the selective ability to remove F, mixing with groundwater or 239 240 remineralization is obligatory to produce water with a satisfactory composition.

241

242 **2.3** Ion exchange technologies

243 Looking back in time it can be seen how synthetic resins, anionic and cationic, are compared in 244 fluoride removal. An example is given by Ku et al., [38], who found that anionic resins are more easily 245 interfered by the presence of foreign ions and are more difficult to be regenerated than cationic resins. The 246 experiments were performed with Amberlite IR-120 which fluoride removal efficiency was highly 247 affected by a pH increase. Essentially, the ion exchange technologies remain unchanged in terms of 248 advantages and disadvantages; although they have high removal efficiency their cost is always high. Also 249 the efficiency in fluoride removal decreases in the presence of other anions, in some cases pH changes and 250 the process is very dependent on the concentration of the ion of interest, in this case, F⁻ ion (Singh et al.) 251 [39].

In many cases the type of material for the membrane or resin is organic with a certain nature (cationic or anionic) and it can function as a matrix for other ions. There are a lot of studies where materials are employed as enhancers for defluoridation capacity over a certain type of membrane or resin. Classical materials in water treatment as zeolite or activated carbon have been employed as ion exchangers. Furthermore, in the case of zeolite due to its large internal surface area and active sites for fluoride adsorption by exchanging Na⁺ bound zeolite with Al³⁺ o La³⁺ ions, as reported by Onyango et al. [40].

A new strategy seems to be the inclusion of metals in certain matrixes to increase the efficiency and selectivity toward fluoride ions. One example is reported by Pan et al., [41], who synthesized a polystyrene anion exchanger that supported hydrous zirconium oxide nanoparticles. Another example is a chemically modified resin with Na⁺ and Al³⁺ (Viswanathan and S. Meenakshi [42]), that increased two times the fluoride uptake.

263

264 2.4 Adsorption process

265 As previously mentioned, ion exchange, electrodialysis and membrane processes are effective and 266 can remove fluoride to a suitable level, however, they are considered a high cost water treatment method 267 and require frequent regeneration and cleaning of the scaling fouling [43,44]. Some advantages and 268 shortcomings of the water treatment techniques usually implemented to remove fluoride from water are 269 reported in Table 1. Adsorption is widely used, especially in developing countries. Industrialized countries 270 generally use more efficient but more costly adsorption media including synthetic ion resins or composite 271 materials combined with reverse osmosis and electrodialysis, while developing countries exploit 272 inexpensive locally available adsorptive media like clays, muds or agro-waste materials [13, 45]. As can 273 been seen, adsorption greatly dependent on the development of adsorptive materials, where the efficiency 274 of this technique mainly depends on adsorbents.

Recent attention of scientists has been devoted to the study of low cost, but effective conventional and non-conventional materials. A large number of adsorbent materials have been tested, such as amorphous alumina [46], activated alumina [47], activated carbon [48], calcite [49], clay [50], and rare earth oxides [51, 52]. Besides, some adsorbents can only work at a certain acid pH value, such as activated carbon which is only effective for fluoride removal at pH less than 3 [53].

Many researchers have developed synthetic sorbents using single or multi-metal oxides/hydroxides for fluoride removal from water, as it will be discussed in the following sections. This review has been focused on the potential of metal oxides/hydroxides/oxyhydroxides, and mixed metal oxides for water defluoridation. The following sections, will present a summary of relevant research in this field in terms of adsorption capacities and kinetics.

285

286 2.4.1 Metallic based adsorbents

These kinds of adsorbents have attracted more attention in recent years due to their high efficiency in almost all of the cases that these were tested for fluoride removal. One of the main obstacles for their implementation is their cost, however, it has been proven that small amounts of metals supported on cheaper materials significantly increase fluoride removal.

291

292 2.4.1.1 Monometallic based adsorbents

The basic reason for using metallic compounds as adsorbents for fluoride removal is based on the nature of these materials. Metallic elements have tendencies to give valence electrons and acquire positive charge that attract negatively charged fluoride ions. The literature shows that the number of publications on monometallic based adsorbents has increased in recent years. The adsorbents based on one metal are relatively few: about 15 different metals have been used for preparing adsorbents for multiple applications. One of the reasons is that many metals have not been used due to their toxicity.

From the first row of the periodic table (lithium, sodium, potassium, rubidium, cesium and francium), lithium is the only metal that has been studied to remove fluoride, but has not been reported as the principal element in the adsorbent, due to its relative high cost. The rest of alkali elements are excluded for the purpose of fluoride removal from water as adsorbents. Sodium could be used to remove fluoride via precipitation. On the other hand, alkali metals have the lowest electronegativity that results in a high affinity to form bonds of covalent predominance. With regard to alkali, the most studied earth metals are calcium and magnesium, which are the most abundant elements in earth's crust.

306 Islam and Patel [54] proposed that among various technologies, fluoride adsorption by using quick 307 lime appeared to be an interesting process. The use of quick lime as adsorbent to remove fluoride has not 308 been clarified, so this study was directed to understanding the adsorption process in a better way. The

309 inconvenience of this adsorbent is that results in chemisorption along with precipitation of fluoride. 310 Removal efficiency was found to be maximum when the initial fluoride concentration was high (>10 mg 311 L^{-1}). Therefore, the removal of fluoride using quick lime cannot be used for domestic purpose, since it 312 cannot bring fluoride concentration within permissible limit, and also increases the pH of the treated water. Nath and Dutta [55] reported acid-enhanced limestone defluoridation in a column reactor. Ca²⁺ 313 314 ions, formed due to dissolution of limestone by oxalic acid, precipitate calcium fluoride along with 315 precipitation of calcium oxalate. A good fluoride removal ability, low residual oxalate, acceptable final 316 pH, low-cost and the simplicity of the process make the acid-enhanced limestone defluoridation process 317 with oxalic acid a potential method for defluoridation of groundwater. There are some other works where the acid used is HCl, H₂SO₄, HNO₃, acetic acid or citric acid. When using strong acids, the remains in the 318 water are Cl⁻, SO_4^{2-} and NO_3^{-} which are undesirable, while acetic and citric acid permit the enhancement 319 320 of fluoride removal. The tests with oxalic acid were in search for a more suitable acid keeping in mind that being a stronger acid it should increase the concentration of Ca^{2+} . Moreover, very little oxalate should 321 322 remain in the treated water due to low solubility of calcium oxalate and high concentration of calcium ions 323 produced in the column. They concluded that the precipitation process is rapid whereas the adsorption is 324 slow and continues beyond 6 h. The adsorption is significant with fresh limestone but decreases with 325 repeated use of the limestone.

326 Another mineral of calcium used for fluoride removal is hydroxyapatite. Badillo-Almaraz et al., [56] 327 reported the use of commercial synthetic hydroxyapatite BIO-RAD and the best physicochemical 328 condition for removing the biggest quantity of fluoride present in drinking water. It is reported that the 329 retention of fluoride in the synthetic hydroxyapatite BIO-RAD diminishes notably as the pH rises. Another study by Gao et al., [57] reported an interesting article named size-dependent defluoridation 330 331 properties of synthetic hydroxyapatite, where the results showed that the better performances in fluoride 332 removal were obtained with the smaller particle size and the efficiency was better at a low pH. On the 333 other hand, Poinern et al., [58] combined ultrasonic and microwave processes to produce nanoparticles of 334 hydroxyapatite, which allowed to control the size and morphology varying the experimental conditions 335 that regulate the particle nucleation and growth. The particles that were produced had a relatively low 336 fluoride adsorption capacity compared with some materials related to the precipitation process such as 337 quick lime, but these have the advantage that the equilibrium pH was 6.6, meaning that it would not be 338 necessary to readjust pH in water for human consumption. Moreover, Wang et al., [59] worked with 339 nanoparticles of hydroxyapatite and added low molecular-weight organic acids to improve fluoride 340 removal. They found that the acids formed new active sites for fluoride adsorption at low pH where acids 341 present a protonated state, and these organic acid anions could be exchanged with fluoride on the surface 342 of hydroxyapatite nanoparticles.

343 Regarding other monometallic-based adsorbents, Nagappa and Chandrappa [60] synthesized 344 mesoporous and nanocrystalline oxide manganese based adsorbents. These were prepared through 345 combustion route and the comparative study for fluoride removal capacity (in standard fluoride solution 10 ppm) showed an adsorption uptake of 97%, while the regenerated material reduced the uptake to 76%. 346 347 Maliyekkal et al., [61] also used synthesized MgO nanoparticles, but employed a cheaper synthesis 348 method than combustion with similar results in fluoride adsorption capacity. It was also reported that 349 phosphate ions affect the fluoride removal. With respect to the methods of synthesis of magnesium oxides, 350 Sasaki et al., [62] found that sorption of fluoride increased when the adsorbent was synthesized at 351 calcination temperatures that are lower than 873 K for 1h. The authors also reported that the process 352 involved co-precipitation of F⁻ with magnesium hydroxide.

353 In addition, the interest of rare earth metals like adsorbents came from the particular properties that 354 most of them exhibit, like multivalence behavior and the selectivity towards fluoride ions. Scandium and 355 vttrium elements behave more like rare earth metals than transitional ones, and since these are extracted 356 from minerals of rare earth metals they could be considered herein. Lanthanum has been studied to remove fluoride from water, for instance, Na and Park [63] used lanthanum hydroxide which showed a 357 defluoridation capacity of 242.2 mg g⁻¹ at pH 7.5, and 24.8 mg g⁻¹ at pH 10. This material presented a 358 sorption energy close to chemical sorption, and the regeneration percentage was 24.9 and 89.7% for 0.1 M 359 360 NaOH and 2.0 M NaOH solutions, respectively. Rao and Karthikeyan [64] also studied the use of lanthanum oxide for fluoride removal and reported that the sorption capacity ranges from 0.5 to 2.5 mg g⁻ 361 ¹, depending upon initial concentration and a higher sorption capacity was accomplished at low pH values. 362 363 The energy of sorbent-sorbate bonding was found to be strong, which indicated a chemisorption process; 364 and alum was a more effective regenerant than HCl and NaOH.

Transition metals have much more interest for fluoride removal by adsorption than alkaline and alkaline earth metals, because of their multivalent behavior and more "places" for the fluoride ion to interact. The transferring electron interactions between these metals and fluoride ions are slightly weak due to the higher electronegativity than alkaline and alkaline earth metals (with the exceptions of Mg and Be) that tend to precipitate fluoride.

The elements mainly used for water treatment are iron, zirconium, titanium and manganese. More than half of the reported studies related to monometallic compounds to remove fluoride use iron compounds. Tang et al., [65] used goethite to simultaneously adsorb arsenic and fluoride, being less favorable for fluoride. Granular ferric hydroxide was studied by Kumar et al., 2009 [66] and Tang et al. [67]. Both coincided that certain anions reduce the fluoride removal in the next order H₂PO₄⁻ >HCO₃⁻ >SO₄²⁻. The first study found that the maximum fluoride removal was 7.0 mg g⁻¹ at 25°C and optimal pH range between 4 and 8. The study of Tang et al., (2009) indicated that maximum fluoride adsorption was

377 achieved between pH 3 and 6.5, whereas the XPS results showed an inner-sphere complexation when 378 fluoride was adsorbed by iron in the granular hydroxide. Iron oxide nanomaterials were studied by 379 Mohapatra et al., [68] and found that this material, composed of different phases of iron oxides, had the 380 best adsorption at pH of 5.75 and that it was severely affected by sulfate and chloride anions. Zirconium adsorbent in form of zirconium oxide showed a maximum fluoride adsorption capacity of 68 mg g^{-1} at pH 381 382 7, and it was concluded that hydrous zirconium oxide was superior to most Zr-containing adsorbents (Dou 383 et al. [69]). Moreover, Swain et al., [70] studied meso-structured zirconium phosphate and reported a 384 maximum adsorption of fluoride at pH 6. Although the process showed bonding energy related to ion 385 exchange, the material was used and regenerated up to five times.

Titanium dioxide has also been studied to remove fluoride, such is the case of Babaeivelni and Khodadoust [9] who reported a maximum fluoride adsorption at a pH range of 2-5. It was also reported that the presence of bicarbonate ion has a negative effect on fluoride uptake, but the selectivity of the material was for fluoride over bicarbonate, sulfate and calcium ions. Wajima et al., [71] reported another adsorbent for fluoride removal, titanium oxysulfate (TiOSO₄•xH₂O), which showed a maximum fluoride adsorption at pH 3.

392 The *p*-block of the periodic table contains the elements Al, Ga, In, Sn, Tl, Pb and Bi. From these, Al, 393 Sn and Bi have been reported as adsorbents for fluoride contained in aqueous solutions. Historically 394 aluminum compounds are the best typical helper material in removal of contaminants from water and have 395 been extensively studied. The research for defluoridation with alumina (Al₂O₃) shows different kinds of 396 compounds which include different treatments to give it specific characteristics. Gong et al., [72] worked 397 with five types of alumina that were poorly crystallized and their anion exchange capacity and point of 398 zero charge varied for each one. Besides, acidic alumina exhibited higher ion exchange capacity with a 399 more positively charged surface and better defluoridation performance (higher adsorption capacity and 400 quicker removal of fluoride) than basic alumina. According to Goswami and Purkait [73], acidic alumina followed the Langmuir model with an adsorption capacity of 8.4 mg g^{-1} and 94% of fluoride adsorbed at 401 402 pH 4.4. There are other kinds of alumina used for defluoridation processes, like one reported by Kamble et 403 al., [74] who used alumina of alkoxide, which is a gamma alumina that contains a small amount of Fe_2O_3 , 404 SiO₂ and has activated carbon in its pores. Kumar et al., [75] worked with nano-alumina, and the 405 maximum fluoride sorption capacity reported was 14.0 mg g⁻¹ at 25 °C and pH 6.15. Liu et al., [76] and 406 Mulugeta et al., [77] have also studied alumina hydroxides to remove fluoride. According to Liu et al., [76], the maximum fluoride adsorption capacity was 110 mg g^{-1} in a pH range from 5.0 to 7.2, where the 407 408 characteristics of low particle diameter, high surface area, and surface reactivity of the amorphous 409 $Al_2O_3 \cdot xH2O$ enable its high removal. The study presented by Mulugeta et al., [77] involved an adsorbent based of aluminum hydroxide with 90% of Al(OH)₂·8(SO₄)_{0.1} and 10.7% of aluminum sulfate and 10% of 410

411 sodium sulfate with impurities. The fluoride adsorption capacity (for continuous packed column experiments at a flow rate of 100 empty bed volumes per day) was 26.2 mg F⁻ g⁻¹. Additionally, Wang et 412 al., [78] concluded that nano-AlOOH possesses a maximum fluoride removal of 3.2×10^{-3} mg g⁻¹, which is 413 414 comparable with the activated alumina, and has a maximum adsorption around pH 7. On the other hand, 415 Srivastav et al., [79] synthesized three forms of bismuth trioxide (Bi_2O_3) that were examined for 416 defluoridation of aqueous solutions. Those three additional bismuth hydro(oxides) (HBOs) were 417 synthesized from Bi₂O₃, HCl and NaOH. The highest removal percentage presented in this work for those materials was ~65% at 10 mg/L of initial fluoride concentration, while commercially available Bi_2O_3 418 419 powder removed approximately only 6% of fluoride. Table 2 shows the comparison of some monometallic 420 adsorbents and their performance for fluoride removal from water.

421

422 2.4.1.2 Bimetallic based adsorbents

In an effort to improve the fluoride adsorption capacity of single metal oxides, researchers havedeveloped bimetallic materials.

425 To enhance the alumina efficacy of fluoride removal, Liu et al., [80] studied the removal of this anion 426 using an Al-based material modified with Ce, Ti, La or Zr. The hybrid Al-La and Al-Zr increased their 427 adsorption capacity around 6.6 and 33%, respectively. Al-Ce possessed the highest adsorption capacity (62 mg g⁻¹) with a Ce/Al molar ratio of 1:4, at pH 6 and 25 °C. The preparation of the hybrid adsorbent 428 Ce-Al by co-precipitation with NaOH and a drying temperature of 80 °C, allowed the formation of 429 430 nanoparticles. SEM and XRD results showed that the bimetallic adsorbent possessed an amorphous 431 structure with some aggregated nanoparticles. The point of zero charge at pH 9.6 showed that fluoride is 432 attracted by electrostatic interactions with -OH exchange from the adsorbent surface. On the other hand, 433 Maliyekkal et al., [81] modified alumina with manganese oxide to prepare a Mn-Al adsorbent, and applied 434 it to defluoridation of drinking water. The optimal pH range for fluoride removal was 4-7, and the 435 maximum adsorption capacity reached with this adsorbent was 2.65 times higher than activated alumina (2.851 mg g⁻¹). Moreover, the adsorption kinetics demonstrated that the manganese-oxide-coated alumina 436 437 was faster than activated alumina, which can be regenerated with 2.5% NaOH.

438 On the other hand, Tripathy and Raichur [82] also studied the effect of manganese dioxide coating on 439 activated alumina in the removal of fluoride. The authors found that the maximum adsorption capacity 440 reported by the Langmuir model was 0.16 mg g⁻¹, and the kinetic studies revealed that the adsorption 441 followed second-order rate kinetics, up to 0.2 mg L⁻¹, at pH 7 in 3 h and at 25°C. In this case, the fluoride 442 adsorption was attributed to physical adsorption.

Bansiwal et al., [83] modified mesoporous alumina with copper oxide to improve fluoride removal from water. The adsorption capacity of the Cu-Al material obtained from the Langmuir model was 7.22

445 mg g⁻¹. The enhancement in the fluoride adsorption capacity was attributed to the increase in zeta potential 446 to more positive values. A decrease in sorption capacities was reported at pH above 8, and might be due to 447 the presence of OH⁻ ions that compete for the same adsorption sites. No leaching of copper occurred when 448 fluoride was adsorbed by the bimetallic material.

Following the co-precipitation methodology, Deng et al., [84] developed a Mn-Ce adsorbent. The highest adsorption capacity was achieved at a Ce/Mn ratio of 1:1, at pH 6 and 25°C. In equilibrium concentrations of 1 mg L⁻¹, the sorption capacity was 79.5 mg g⁻¹ for the powder adsorbent and 45.5 mg g⁻¹ for the granular one. Furthermore, kinetics studies showed that the adsorption process took place in the first hour, when the granular form of the adsorbent required 3 h to reach equilibrium, while the powder accomplished it at 8 h.

Fe-Ti, another bimetallic oxide, was studied for water defluoridation by Lin et al. [85]. The optimized 455 Fe-Ti ratio was 2:1 with an adsorption capacity of 29.85 mg g^{-1} at 25°C. It was found that the hydroxyl 456 457 groups and Fe-O-Ti bonds on the adsorbent surface which provided active sites for adsorption: a Fe-O-F 458 bond is formed after F removal. Biswas et al., [86] incorporated Sn(IV) to iron(III) oxide, and the 459 maximum fluoride adsorption capacity was 10.50 mg g^{-1} in a pH range 5.0-7.5. This trend was presumably due to the neutral or near neutral surface of the solid. The hybrid adsorbent can be regenerated up to a 460 level of 75 % with a bicarbonate solution, at pH 13. Previously, the same group developed a crystalline 461 and hydrous Fe(III)-Zr(IV) hybrid oxide for fluoride removal [87]. The optimum Fe/Zr ratio was 9:1, and 462 463 the pH range for F⁻ uptake was between 4.0 and 7.0. The pH_{ZPC} determined for the oxide was 7.1-7.2, and the maximum adsorption capacity was 7.51 mg g⁻¹, at 20 °C and pH 6.8. The kinetic data obtained for 464 465 fluoride removal described both the pseudo-first and the reversible first order equations. The kinetics also 466 demonstrated that the fluoride adsorption took place with a boundary layer diffusion. The external mass 467 transport with intra-particle diffusion phenomena governed the rate, limiting the process. Duo et al., [88] 468 developed another Zr-Fe adsorbent using an extrusion method that was composed of amorphous and nano-469 scale oxide particles. The optimum Zr/Fe ratio was around 2.3, and the adsorption capacity reached with this material was 9.80 mg g⁻¹ under an equilibrium concentration of 10 mg L⁻¹ at pH 7. Moreover, it had an 470 471 excellent mechanical stability and high crushing strength. The fluoride adsorption followed a pseudosecond-order kinetics, and the presences of Cl⁻, NO₃⁻ and SiO₄⁴⁻ did not inhibit the fluoride uptake, except 472 for HCO_3^{-} , PO_4^{-3-} and AsO_4^{-3-} . The authors tested the granular bimetallic adsorbent in columns using real 473 474 water and the results showed that it has high potential for fluoride removal.

Ti-Ce and Ti-La were prepared by Zhijian et al., [89] to enhance the fluoride adsorption capacity, in which the doping Ce and La oxides increased the points of zero charge in the zeta potentials of the hybrid adsorbents. At their points of zero charge, Ti-La and Ti-Ce (pH_{ZPC} = 6.8 and 6.2) adsorbed 18.7 and 22.6 mg g⁻¹, respectively, at a fluoride initial concentration of 10 mg L⁻¹. The sorption equilibrium was

achieved in 4 h where the pseudo-second order model described the sorption kinetics, besides, the
nonspecific electrostatic attraction and the specific anion exchange with hydroxyl groups were mainly
responsible for fluoride adsorption in the bimetallic adsorbents.

482 An iron-doped titanium oxide adsorbent was developed by Lin et al., [90]. This adsorbent had a maximum fluoride adsorption capacity of 53.22 mg g⁻¹ at pH 7 and 25 °C, obtained by fitting the 483 experimental data with the Langmuir isotherm model. The adsorption of fluoride followed a second-order 484 485 kinetic. The authors prepared the adsorbent with an initial feed Fe/Ti molar ratio of 1, but a 0.35 molar 486 ratio was used during the optimization because the Ti ions precipitated faster and earlier than Fe ions 487 during the titration procedure used. It was found that the Fe doped into Ti oxide promoted the formation of 488 active hydroxyl groups on the adsorbent surface, and it increased the fluoride adsorption capacity. The 489 difference between the previous work by the same research group [85] and this study is that the feed molar 490 ratio of Fe/Ti and the pH were lower, and the washed process included just water instead of ethanol. Thus, 491 the differences in the synthesis process gave the iron-doped titanium oxide adsorbent a higher adsorption 492 capacity than Fe-Ti bimetallic oxide.

Following the mixed oxides, Biswas et al., [91] synthesized an iron(III)-aluminum(III) adsorbent for fluoride removal from water. The results demonstrated that the optimum Fe/Al ratio was 1, and the maximum adsorption capacity was 17.73 mg g⁻¹ at pH 6.9, and 28 °C. The authors established that this mixed oxides could be a better adsorbent than either of the pure oxides. The equilibrium data were fitted reasonably with the Langmuir and Redlich-Peterson models, and the equilibrium was reached in 1.5 h. Moreover, the pseudo-second-order model described the adsorption kinetics, and the adsorption rate was controlled by multistage diffusion.

500 Iron has also been used as an active agent in nanotechnology and this nanosized form has been 501 studied for defluoridation of water since several years ago. For instance, a material composed by 502 aluminum oxide embedded with Fe_2O_3 nanoparticles ($Fe_2O_3@Al(OH)_3$) was prepared by Zhao et al., for 503 fluoride removal from aqueous solutions [92]. The adsorbent, in the range of 240-340 nm, presented 504 magnetic properties which can be an advantage for the easy separation from sample solutions by the 505 application of an external magnetic field. The optimal ratio Fe₂O₃/Al(OH)₃ was 2:5, and the adsorption capacity calculated by the Langmuir model was 88.49 mg g⁻¹ at pH 6.5 and 25°C. The authors reported a 506 residual fluoride concentration of 0.3 mg L^{-1} when using Fe₂O₃@Al(OH)₃ nanoparticles, with an initial 507 508 concentration of 20 mg L⁻¹, which met the standard of the World Health Organization (WHO) for safe 509 drinking water quality. Recently, Chai et al., [93] also developed sulfate-doped Fe₂O₃/Al(OH)₃ magnetic 510 nanoparticles for fluoride removal from water. The authors reported a maximum fluoride adsorption capacity of 70.4 mg g^{-1} at pH 7 and 25°C, where the fluoride sorption process can be achieved within 20 511 min with a 90% of F^{-} removal. SO_4^{2-} was released steadily from the nanoparticles with simultaneous 512

513 fluoride adsorption, indicating that an anion exchange mechanism took place during the fluoride removal.

514 The difference between this research and that conducted by Zhao et al., [92] is that the pH range for

515 fluoride adsorption was from 4.0 to 10.0, indicating the applicability of this developed nanoadsorbent for 516 water defluoridation.

517 The rare earth oxides occur as a mixture of various oxides, Raichur et al., [52] used these elements as 518 mixed rare earth oxides to remove fluoride from aqueous solutions. The chemical material composition 519 was a mixture of La₂O₃ (44%), CeO₂ (2%), Pr₆O₁₁ (10.5%), Nd₂O₃ (36.5%), Sm₂O₃ (5%), among others in trace amounts. The maximum fluoride adsorption capacity was 196.08 mg g⁻¹ at pH 6.5 and 29 °C, where 520 521 most of the adsorption took place in the first 10 min. The adsorption followed the Langmuir isotherm model and it was found that sulfate and nitrate, up to 100 mg L^{-1} , did not greatly affect the fluoride uptake. 522 523 Adsorption studies demonstrated that fluoride can be desorbed at pH 12. However, the adsorption 524 efficiency decreased from 98 to 91% after the first regeneration.

525 Several layered double hydroxides (LDH) have been developed in order to make efficient fluoride 526 removal from water supplies. These mixtures are a family of lamellar compounds containing anions in the 527 interlayer space and have been recently focused on the synthesis of new hybrid materials for fluoride 528 removal from water. A recent study carried out by Kim et al., [94] demonstrated that the removal of high 529 fluoride concentrations by Mg/Al layered double hydroxides can be useful. Batch experiments 530 demonstrated that the optimal adsorbent was performed calcinating the Mg/Al LDH at 700 °C, while the 531 X-ray analyses indicated a chemical composition of mixed metal oxides $(Al_8O_3N_6+Mg_{0.44}Al_{0.55})$ and 532 magnesium oxide (MgO), respectively. Batch experiments showed that the fluoride sorption capacity was 533 1.7-2.9 times greater than Mg/Al calcined at a temperature less to 300°C, and the adsorption capacity was 91.4 mg g^{-1} . The kinetic data showed that the fluoride sorption arrived at equilibrium after 12 h. Moreover, 534 535 fluoride sorption decreased considerably in the presences of anions such as phosphate, sulfate and 536 carbonate.

537 Following the modification of adsorbents that contain Magnesium, Kang et al., [95] evaluated the 538 calcinated Mg/Fe layered double hydroxide (Mg/Fe-CLDH) as a material for fluoride and arsenate 539 removal from aqueous solutions. The adsorbent was synthesized by a co-precipitation method and the 540 optimal Mg/Fe ratio was 5, calcinated at 400 °C, and the maximum adsorption capacity reached with this 541 material was 50.91 mg g⁻¹ at pH 7. Data of equilibrium experiments were fitted by the Langmuir isotherm 542 model and pseudo-second order kinetic. The fluoride adsorption mechanism involved surface adsorption, 543 ion exchange interaction and the original layered double hydroxide (LDH) structure was reconstructed by 544 rehydration of mixed metal oxides and the intercalation of F ions into the interlayer region.

545 MgAl-CO₃ was developed by Luv et al., [96] to treat high fluoride concentration solutions (5-2500 mg L^{-1}). The adsorbent was prepared by a co-precipitation method as well, and the maximum adsorption

547 capacity of this LDH containing carbonate, where the data was fitted with the Langmuir-Freundlich 548 model, was 319.8 mg g⁻¹ at pH 6 and 30°C. The kinetic experiments showed that the fluoride adsorption 549 involves a rapid first order step and a slow second order step, and suggested that the second step was 550 controlled by diffusion. It was found that the fluoride removal decreased in presence of other anions in the 551 order of HCO_3 -CI- H_2PO_4 - SO_4^{2-} , and the interlayer CO_3^{2-} of the LDH can be partially removed under 552 acidic conditions, with concomitant incorporation of fluoride in the interlayer galleries of the LDH's.

Batistella et al., [97] also tested MgAl containing CO_3^{2-} layered double hydroxide activated in acidic conditions like HCl and HCOOH as reducing and complexing agents, respectively. The adsorption assays showed that an enhancement in adsorption was verified at pH 3.5 and a temperature of 50 °C. The high adsorption capacity reached with these conditions was 303.54 mg g⁻¹ within 10 min of contact time and 0.19 M HCOOH, which was slightly higher than what was reported previously [91].

558 Recently, Zhang et al., [98] tested a lamellar compound named CeO₂/Mg-Fe layered double 559 hydroxide composite for fluoride removal from water. In order to improve the fluoride removal efficiency, 560 non-thermal plasma (NTP) was used to modify the surface of these composites. The optimum Ce/Fe mol 561 ratio was 3/5 at 420 °C. The experimental results indicated that the adsorption was 52.4 mg g⁻¹ at pH 6-7 and 25 °C. The kinetic adsorption data was found to fit the pseudo-second order model, while the 562 equilibrium data was described by the Langmuir model. Also, the same research group developed another 563 564 layered double oxide composed (Li-Al-LDH) by a co-precipitation method [99]. The results indicated that the maximum adsorption capacity reached with this adsorbent increased from 34.77 to 42.43 mg g⁻¹ as the 565 temperature increased from 10 to 40 °C, at pH 7. Besides, the adsorption kinetics of fluoride were 566 567 represented by the pseudo-second-order model and the experimental data were fitted by the Freundlich 568 isotherm model. It was also stated that from the kinetics analysis, chemisorption may be involved in the 569 adsorption process and can be inferred that an ion-exchange was implicated in a second adsorption stage.

570

571 2.4.1.3 Trimetallic based adsorbents

It has been presumed that multimetal mixed oxides may be good for filtering materials and for scavenging high fluoride concentrations from contaminated water. Furthermore, it has been assumed that multimetal mixed oxides may be the natural key material in scavenging fluoride from the fluoride-rich percolated water [100].

In this context, Wu et al., [101] used a Fe-Al-Ce trimetal oxide in order to improve the adsorption capacity of the Fe-Ce bimetal oxide. The results of their study show that the maximum fluoride removal (95%) was achieved with an adsorbent calcined at 300 °C, achieving a fluoride adsorption capacity of 178 mg g⁻¹ at pH 7. The one-site and two-site Langmuir isotherm models were applied to fit the isotherm. The experimental data were better fitted by the two-site Langmuir isotherm (R2 = 0.992 and Qmax = 229 mg

g⁻¹), suggesting that there might exist two adsorption sites with different adsorption energies on the 581 582 adsorbent surface. The optimum pH for fluoride uptake was 6.0-6.5. However, the adsorbent also showed 583 a high adsorption capacity over a relatively wide pH range of 5.5-7.0, were the pH_{ZPC} of this adsorbent was 7.5. The adsorption kinetic constant values of the first order rate (k) was determined as 0.002 and 584 0.0029 min⁻¹, respectively; and for concentrations of 10 mg L^{-1} and 50 mg L^{-1} the correlation coefficients 585 (r^2) were 0.978 and 0.982, respectively. Adsorption fluoride was partially inhibited by high concentrations 586 587 of phosphate or arsenate, and was not affected by the presence of chloride, sulfate, or nitrate. Desorption 588 results and column experiments further indicated the practicality of trimetal oxide Fe-Al-Ce to remove 589 fluoride for water.

590 The same group, Wu et al., [102], reported that increasing the initial fluoride concentration, the zeta 591 potential becomes more negative in the range of pH 4-10. To elucidate the fluoride adsorption mechanism 592 by Fe-Al-Ce, XPS and 19F Mass-NMR were used in combination to identify the adsorption of F⁻ on Al-Fe-Ce. They found a ligand exchange relationship between hydroxyl groups and metal-ions F⁻. -OH 593 594 groups had contributed to adsorption of F, and although the Fe-Al-Ce contains a low proportion of Ce, 595 Ce-OH was the preferred site for adsorption at low loads of F. Al-F became the most abundant kind of complex at higher load, which could be related to the high molar ratio of Al in the adsorbent. Al₃-F, Ce_x-596 F_{y} , F_{y} and Al_{3} Fe_{x} -F were identified as fluorinated species after the adsorption process. 597

598 On the other hand, Biswas et al., [103] studied the fluoride removal efficiency of trimetal mixed 599 oxide (HIACMO) synthetic hydrated iron(III)-aluminum(III)-chromium(III) from an aqueous solution. 600 The HIACMO was synthesized by a simple chemical precipitation method. The HIACMO optimal pH for 601 fluoride adsorption was observed in a range of 4.0-7.0. The time required to reach the equilibrium was 1.5 602 h, and the kinetic data followed the equation of pseudo-second order. Equilibrium data were described by 603 the Langmuir isotherm model, and the maximum adsorption capacity reported was 31.8 mg g⁻¹.

604 Furthermore, Raichur and Basu [52] studied the efficacy of mixed rare earth oxides in the fluoride 605 adsorption synthetic solutions. Likewise, they studied the adsorption kinetics, the pH effect, the initial 606 fluoride concentration, the adsorbent dose and the presence of other anions in the fluoride adsorption 607 efficiency. The characterization results showed that the adsorbent's particle size was of $4.34 \mu m$, which 608 had a surface area of 6.75 m² g⁻¹. The adsorption kinetics results demonstrated that during the first 5 609 minutes, the higher amount of fluoride was adsorbed. They found that the adsorption capacity was 12 mg 610 g^{-1} . Also, a dose of 8 g L⁻¹ of adsorbent (at pH 6.5 and fluoride concentration of 50 mg L⁻¹) gave 98.5% of fluoride elimination. The maximum fluoride adsorption was held in the range of 6 to 6.5 with an 611 adsorption capacity of 12.5 mg g⁻¹, which corresponded to the Langmuir model. Anions such as nitrate 612 613 and sulfate affected fluoride uptake. They also reported that desorption of fluoride occurs at pH 12 and

- 614 that the adsorption efficiency decreased from 98 to 91% after the first regeneration. Table 3 shows the 615 adsorption capacity of selected multimetallic adsorbents for fluoride removal from aqueous solutions.
- 616

617 2.4.2 Metal-impregnated based adsorbents

618 2.4.2.1 Carbon based adsorbents

Although carbon based adsorbents poorly remove fluoride from water, their carbonaceous matrix
 provides a high surface area and inhibits metal sintering in their pore structure. These properties allow
 modifying the carbons surface with metals to increase their fluoride adsorption capacity.

622 Cerium dispersed in carbon was reported by V. Sivasankar et al., [104]. This material was prepared 623 by a carbonization of ammonium cerium sulfate impregnated with starch. The maximum fluoride uptake was determined to be 52 mg g⁻¹ at a pH value of 8. Hernandez-Montoya et al., [105] also developed an 624 625 activated carbon by modifying nutshell with a calcium solution derived from an eggshell. The authors reported an adsorption capacity of 2.3 mg g⁻¹ at 30°C, and found that the calcium chemical species on the 626 627 carbon surface were more important than the carbon textural parameters in the fluoride adsorption process. 628 The presence of sulfate and hydrogencarbonate decreased the adsorption capacity, showing that both limit 629 the selectivity of Ca-impregnated activated carbon.

Another research group by Tchomgui-Kamga et al., [106] developed activated carbons that were 630 impregnated with 1M mixture of Al and Fe salts, followed by carbonization at temperatures between 500-631 900 ° C. The optimum adsorbent was carbonized at 650 °C. It was found that the maximum adsorption 632 capacity was 13.64 mg g⁻¹ at 28°C, and more than 92% removal of fluoride was achieved within 24 h at 633 634 pH 7 with a 10 mg L^{-1} of F⁻ initial concentration. The kinetic data showed that the adsorption process followed a pseudo-second order model at neutral pH, it was possible to find a residual amount of Al and 635 636 Fe of 0.67 and 1.8 mg L^{-1} , respectively. These materials showed the presence of crystallized CaCO₃ and 637 CaO. Despite this content, all the charcoals showed acidic surface properties and points of zero charge (pH_{PZC}) values between 7.4–7.7. The fluoride removal was not modified by the presence of NO₃⁻, SO₄²⁻ 638 and PO_4^{3-} , while HCO_3^{-} and Cl^{-} slightly affected the defluoridation capacity. Levva et al., [48] also 639 640 synthesized aluminum-impregnated carbon with 3 to 5 times higher fluoride adsorption capacity. It was 641 reported by Ma et al., [107] that granular activated carbon (GAC) coated with manganese oxides like 642 MnO_2 and Mn_3O_4 improved the fluoride removal by at least three times. This material presented 643 amorphous characteristics and the predominant valence on manganese was 4.

Materials including zirconium are the most studied to remove fluoride from water. Janardhana et al., [108] investigated the potential of a zirconium-impregnated activated charcoal. This material showed a fluoride adsorption capacity of 3–5 times higher than plain activated charcoal. Zirconium impregnated coconut fiber charcoal (ZICFC) was developed by Sathish et al., [109] and showed a maximum fluoride

648 uptake followed by groundnut shell and coconut shell charcoals. Regeneration of ZICFC was conducted 649 by an elution of 0.02 M NaOH solution. Carbon nut shell carbon was also impregnated with zirconium by 650 Alagumuthu and Rajan [110] who found that the optimum conditions to remove fluoride from water (1.83 mg g^{-1}) were pH 7, particle size of 53 um and room temperature (303K). This adsorbent could be 651 652 regenerated 96.2% with 2.5% sodium hydroxide in 180 min. Moreover, the equilibrium sorption data 653 agreed reasonably well with the Langmuir isotherm model, and the sorption dynamic study revealed that 654 the sorption process followed the pseudo-second-order equation; the sorption process was complex, both 655 at the boundary of liquid film and intra-particular diffusion contributed to the rate-determining step. On 656 the other hand, Li et al., [111] synthesized a manganese oxide coated graphene oxide that presented 8.34 times more fluoride removal than graphene oxide. The maximum adsorption capacity was 11.93 mg g^{-1} 657 658 and the optimum removal of fluoride occurred in a pH range of 5.5–6.7.

Our research group has tailored an activated carbon modified with Zr(IV) and oxalic acid [112], that presented 3 times higher fluoride adsorption capacity (5.94 mg g⁻¹) than both Zr-impregnated coconut fiber carbon [109] and Ca-impregnated nutshell carbons [106], at pH 7, Ce= 40 mg L⁻¹ and 25°C. We also found that without the presence of the organic acid, the adsorption capacity increased by only 32%, and the kinetics studies revealed that the Zr-impregnated activated carbon removed 71% of the initial fluoride concentration in the first 15 minutes, reaching equilibrium in 50 min. Table 4 shows the comparison of some carbon based adsorbents and their performance for fluoride removal from water.

666

667 2.4.2.2 Biosorbents and natural materials (clays, zeolites, minerals, mud) modified with metals

Biosorbents normally refer to naturally occurring biomasses or spent biomasses that passively bind 668 669 to organic molecules or metal ions by a phenomenon commonly referred to as biosorption [113-115]. It 670 was reported in the literature that the presence of chemical functional groups such as hydroxyl, carbonyl, 671 carboxyl, sulfhydryl, theioether, sulfonate, amine amide, imidazole, phosphonate and phosphodiester 672 present on the biosorbents surface contribute to biosorption [115-116]. Applications of biosorbent/biomass 673 from various microbial sources, leaf-based adsorbents and water hyacinth have been reported by various 674 investigators [117-123]. Moreover, biosorbents have been modified with metal ions to improve their 675 natural adsorption capacity.

In this subject, Yao et al., [124] used neodymium-modified chitosan for defluoridation of water. The treatment conditions were optimized at pH 7, 323 K and a particle size of 0.10 μ m. The equilibrium sorption data were also fitted reasonably well by the Langmuir isotherm model. The maximum equilibrium sorption was 22.38 mg g⁻¹ at 303 K. Sorption dynamic studies revealed that the sorption process followed a pseudo-second-order equation; and showed that the sorption process was complex where the boundary of liquid film and intra-particle diffusion contributed to the rate-determining step. The

used adsorbents were regenerated with 4 g L⁻¹ of NaOH during 24 h. Following this theme, Sundaram et al., [125] used a bioinorganic composite named nano-hydroxyapatite/chitosan (n-HApC) composite which could be employed for water defluoridation. It was observed that there was a slight enhancement in the defluoridation capacity of n-HApC composite (1.56 mg g⁻¹) compared to nano-hydroxyapatite (n-HAp), which showed a fluoride uptake of 1.29 mg F⁻ g⁻¹. Other contributions by Sundaram et al., [126-127] reported that nano-hydroxyapatite/chitosan composites, showed an increase in fluoride adsorption capacity from 1.29 mg g⁻¹ to 1.56 mg g⁻¹, and concluded that the use of chitosan is justified by its biocompatibility.

Jagtap et al., [128] also studied a modified chitosan-based adsorbent for defluoridation of water. 689 690 The authors showed that when keeping constant the adsorbent dose of 1 mg L^{-1} , pH 7.03, 150 rpm and a contact time of 24 h, an increase of initial fluoride concentration decreased the percentage of removal of 691 692 fluoride, while the adsorption capacity increased (9 mg g^{-1}). This was attributed to the amount of fluoride 693 ions available for adsorption as the concentration increases. Another study that involved biopolymers is 694 that by Kamble et al., [129] who studied the applicability of chitin, chitosan and 20%-lanthanum 695 incorporated chitosan (20% La-chitosan) as adsorbents for fluoride removal from drinking water. The 696 effects of physico-chemical parameters such as pH, adsorbent dose, initial fluoride concentration and the presence of interfering ions during the adsorption were studied. The authors observed that the maximum 697 fluoride uptake was 3.1 mg g⁻¹ at pH 6.7 and an adsorbent dose of 1.5 g L^{-1} . The equilibrium adsorption 698 data were fitted reasonably well with the Freundlich isotherm model, and the presence of chloride, sulfate, 699 700 carbonate and bicarbonate ions in drinking water greatly affected the fluoride uptake. These results 701 indicated that the anions compete with sorption of fluoride on 20% La-chitosan. The adsorption rate was 702 considered rapid, and the maximum fluoride uptake was attained within 20 min. Following with chitosan as biosorbent, Bansiwal et al., [130] used lanthanum incorporated chitosan beads (LCB) to remove 703 704 fluoride from water. The equilibrium adsorption data was fitted by the Langmuir isotherm model and showed a maximum fluoride adsorption capacity of 4.7 mg g^{-1} at pH 5 with negligible lanthanum release. 705 706 Additionally, kinetic studies revealed that fluoride uptake was fast, and follows a pseudo-first-order 707 kinetics, whereas the presence of sulphate, nitrate and chloride marginally affected the removal efficiency, 708 however, drastic reduction in fluoride uptake was observed in the presence of carbonate and bicarbonate. 709 Thakre et al., [131] and Bansiwal et al., [130] agreed that the optimum loading of lanthanum was 10% and that the maximum fluoride adsorption capacity of lanthanum incorporated in chitosan beds is 4.7 mg g^{-1} . 710 711 Chitosan flakes impregnated with lanthanum were studied by Jagtap et al., [132] in which the loading of lanthanum was 20% and found a maximum adsorption capacity of 1.27 mg g⁻¹. They mentioned that the 712 713 advantage of using chitosan over other supports like cellulose, activated carbon and alumina is that 714 chitosan contains amino groups that have the ability to bind with the metal ions by forming complexes.

715 Following with modified chitosan for fluoride removal, Viswanathan and Meenakshi [133] 716 developed a chitosan doped with Fe and they found that the fluoride adsorption capacity rose from 0.052 to 4.23 mg F⁻ g⁻¹. In addition, the same group (Viswanathan and Meenakshi [134]) doped chitosan with 717 Zr(IV), as well as Liu et al., [136] who loaded Zr(IV) in carboxylated chitosan beads. The first authors 718 compared the defluoridation capacity of Zirconium modified chitosan (4.85 mg g⁻¹) with carboxylated 719 chitosan beads and raw chitosan beads which adsorbed 1.385 and 0.052 mg $F^{-}g^{-1}$, respectively. Liu et al., 720 [135] synthesized a bio-based Zr(IV) impregnated dithiocarbamate modified chitosan bead material and 721 722 found a defluoridation capacity of about 4.58 mg F⁻ g⁻¹ at pH 7.0, 30 °C and 40 min. With respect to impregnated chitosan with aluminum, Swain et al., [136] found that the percentage of fluoride adsorption 723 was 84% for the first cycle operating batch study, with an initial concentration of 10 mg L⁻¹, and had a 724 725 good desorption capacity of 92% at pH 12. Furthermore, Viswanathan and Meenakshi [137] developed an 726 alumina/chitosan composite for defluoridation and found an enhanced capacity of 3.81 mg g⁻¹ in comparison with alumina and chitosan that showed an adsorption capacity of 1.56 and 52 mg g^{-1} , 727 728 respectively. Neodymium-modified chitosan was employed for defluoridation by Yao et al., [124] where 729 the maximum sorption equilibrium was between $11.41-22.38 \text{ mg g}^{-1}$, depending on the temperature (283– 323 K), pH (5–9), adsorbent dose (0.2–2.0 g L^{-1}), particle size (0.10–0.50 mm) and presence of co-anions 730 $(NO_3^-, Cl^- \text{ and } SO_4^{2^-})$. Moreover, the adsorbents could be regenerated in 24 h by 4 g L^{-1} of sodium 731 732 hydroxide.

733 Some other biosorbents have also been evaluated to remove fluoride from water. Ramanaiah et al., 734 [138] used waste fungus (Pleurotus ostreatus 1804 SP) and reported that the fluoride-fungal interaction fit 735 a pseudo-first-order rate equation. The amount of fluoride adsorbed per unit mass of fungus showed an increasing trend up to 20 mg L⁻¹, and the experimental data fitted well the Langmuir's adsorption isotherm 736 737 model with an adsorption capacity of 1.27 mg g⁻¹ at pH 7 and 30 °C. Desorption was more evident in an 738 inorganic solution and distilled water. Besides, the effect of temperature on the degradation of the 739 fluoride-loaded biosorbent was also studied for its disposal ability. On the other hand, Mohan et al., [120] 740 employed algal Spirogyra 101, and showed its ability to remove fluoride from aqueous phase. Batch sorption studies performed on the algal-fluoride system indicated an adsorption capacity of 1.272 mg g⁻¹. 741 742 which was more effective with a low pH (2 to 5). The initial high uptake of fluoride was attributed to 743 chemisorption interactions, and the fluoride-algal interactions were corroborated with the pseudo-first-744 order rate equation.

Cellulose is the most abundant renewable biopolymer on earth, and has a low cost and is a promising raw material to synthesize adsorbents for defluoridation of aqueous solutions. Yu et al., [139] found that the agglomeration of nano-size hydroxyapatite (HA) can be avoided by using cellulose as a template to disperse nano-size HA in the cellulose matrix. This adsorbent combines the advantages of

749 cellulose and HA for fluoride removal, moreover, the composite materials showed a higher adsorption 750 capacity than the nano-size HA. It was also reported that the residual fluoride concentration in drinking 751 water could meet the drinking water standard established by the World Health Organization (WHO) by using more than 3 g L^{-1} of adsorbent in the initial fluoride concentration of 10 mg L^{-1} . Another composite, 752 Fe(III)-loaded ligand exchanged cotton cellulose adsorbent (Fe(III)LECCA), was synthesized by Zhao et 753 754 al., [140]. This matrix was selected for being an inexpensive and biodegradable carrier, and a macroporous 755 cellulose material with high surface area while Fe(III) was considered due to its strong affinity towards 756 fluoride anions, environmental safety and low cost. The adsorption followed a first-order rate reaction and the adsorption capacity was 18.6 mg g⁻¹ at 25 °C. The leakage of Fe(III) from the adsorbent was just 757 758 below 0.3 mg L⁻¹ due to the strong complex action between phosphonomethy amino group of LECCA and the chelating center Fe(III). On the other hand, in column experiments, with 20 mg L^{-1} influent fluoride at 759 26 BV h⁻¹ flow rate under 25 °C, the column gained 5.6 mg g⁻¹ breakthrough adsorption capacity and 760 761 NaOH regeneration was effective in up to 8 adsorption-desorption cycles.

762 Among natural adsorbents, Suzuki et al., [141] and Xu et al., [142] developed a defluoridation 763 water-kaolinite-MgO system and magnesia-loaded fly ash cenospheres (MLC), constituted with silica and 764 alumina, respectively. The modified MgO was proposed with the final objective of evaluating the use of 765 commercial-grade MgO as a fluoride immobilization agent in soils. The studies of sorption with enough 766 MgO added to the water-kaolinite (soil model) system worked better for defluoridation and it was 767 considered as a reliable immobilizer for fluoride ions. Commercial-grade MgO had a fluoride adsorption capacity of 64 mg g⁻¹ at pH 11.5, and the fluoride adsorption mechanism was attributed to its 768 incorporation into the Mg(OH)₂ by –OH substitution. Furthermore, the dominant fluoride immobilization 769 770 agent for soils was kaolinite. In addition, a series of fluoride leaching tests showed that kaolinite without 771 MgO is vulnerable to an alkali attack, and the fluoride desorption from the contaminated kaolinite took 772 around 3-4 days. On the other hand, magnesia-loaded fly ash cenospheres [142] had a maximum fluoride adsorption capacity of 6 mg g⁻¹ at pH 3 and 45 °C. The coexisting ions had a large impact 773 774 (phosphate>nitrate>sulfate) on the fluoride sorption on MLC, and the experimental data fitted well the 775 pseudo-second order kinetic model and followed the Langmuir isotherm.

Orange waste, and its modification with metal ions, has also been studied for water defluoridation. For instance, Zr(IV) was loaded on a dried orange juice residue (Zr(IV)-DOJR) by Paudyal et al., [143]. The optimal parameter in the fixed bed column for Zr(IV)-DOJR that removed 13.9 mg g⁻¹ were 14.3 mg L⁻¹ of influent fluoride concentration, 1.2 cm of bed depth and 2.55 ml min⁻¹ of flow rate. The breakthrough time was 50 min., and the breakthrough curve model showed that Thomas and the Bed Depth Service Time (BDST) models were in agreement. Furthermore, dilute alkali (0.1 NaOH) solution was effective to desorbed fluoride from the loaded column. The same authors [144] prepared an adsorbent

with rare earth metal ions and orange waste with a saponification reaction using lime for water defluoridation. The maximum adsorption capacity for fluoride was reported at 0.60, 0.92, 1.06 and 1.22 mmol g⁻¹ for Sc (III), Ho (III), La (III) and Sm (III) loaded adsorbent, respectively. They concluded that the La(III)- and Sm(III)- saponified orange juice residue (SOJR) had stronger interaction with fluoride ions even with a trace concentration, suggesting that these materials can be employed as effective adsorbents for the treatment of industrial effluents containing a trace concentration of fluoride ions.

Rice husk ashes and aerobic granules were also evaluated to remove fluoride from water, as reported by Ganvir and Das [145] and Wang et al., [146], respectively. In the first study, the authors coated the biosorbent with aluminum hydroxide and found a high fluoride adsorption capacity of 19 mg g⁻¹. On the other hand, the aerobic granules, self-aggregation of microorganisms, were modified with Ce(III). Those granules showed a fluoride adsorption capacity of 45.80 mg g⁻¹ at a neutral pH, that corresponded to an increase of 359 % compared to the pristine aerobic granules. Also the highest adsorption capacity occurred in the pH range of 3.0 to 5.0.

796 Alginate beads doped with Fe(III) or La(III) were studied by Sujana et al., [147] and Huo et al., 797 [148], respectively. Hydrous ferric oxide doped alginate beads [149] worked better between pH 3.5 and 5, 798 although their adsorption capacity was significant (45-55%) around neutral pH. The beads were 0.8-0.9 799 mm size and contained 32-33 % Fe(III), and showed a specific surface area of 25.8 m² g⁻¹ and a pH_{PZC} of 5.15. Modified beads showed a Langmuir F⁻ adsorption capacity of 8.9 mg g⁻¹ at pH 7 and the adsorption 800 kinetics were described by the pseudo-second order kinetic model followed by an intraparticle diffusion as 801 the rate-determining step. Moreover, lanthanum alginate beads [148] showed that the fluoride adsorption 802 803 isotherm was well fitted by the Langmuir model, and the maximum adsorption capacity was 197.2 mg g^{-1} at pH 4. The amount of La(III) in the alginate beds was 25 % with a specific surface of 4.05 m² g⁻¹. Also, 804 805 the mechanism involved in fluoride adsorption by lanthanum alginate beads was an ion-exchange between F⁻ and Cl⁻ or OH⁻. Another research group by Zhou et al., [149] reported that the La³⁺-impregnated cross-806 807 linked gelatin exhibited the maximum adsorption capacity of 98.8 % with a pH range of 5-7 (21.28 mg g⁻ 808 ¹), while the adsorption followed a first-order reaction. Moreover, the adsorption capacity decreased to 809 82.3% after the adsorbent was regenerated three times with 1 M NaOH. Table 5 shows the adsorption 810 capacity of modified biosorbents and natural materials for fluoride removal from aqueous solutions.

811

812

2.4.2.2.1 Synthetic resins, ceramics and polymers

813 Chen et al., [150] developed an iron-impregnated granular ceramic for water defluoridation. This 814 material was prepared with Kanuma mud, zeolite and starch, with $FeSO_4 \cdot 7H_2O$ or Fe_2O_3 . It was found that 815 the granular ceramic with $FeSO_4$ was more effective for fluoride removal than the one that contained 816 Fe_2O_3 . The maximum fluoride adsorption on ceramic-FeSO₄ at pH 7 was 94.2 %, and the equilibrium data

817 was well fitted by both Langmuir and Freundlich models. Kinetics were governed by intraparticle 818 diffusion and followed a second-order kinetics model. The particle size was around 3-5 mm, which would 819 not block the sewer and could be easily separated from water. On the other hand, a hybrid sorbent of 820 Zr(IV)-ethylenediamine was synthesized by Swain et al., [151] where the combination of zirconium(IV) 821 and ethylenediamine reaction lead to the formation of a kind of gel material. The maximum fluoride removal (37.03 mg g⁻¹) was performed at pH 7, while the adsorption process followed a pseudo-second 822 order kinetic model. The fluoride adsorption mechanism onto Zr(IV)-ethylenediamine adsorbent 823 824 suggested an ion exchange mechanism fluoride –OH groups . Moreover, the presence of NO_3^{-1} , Cl⁻ or SO_4^{-2} 825 did not have significant impact on fluoride removal.

Polystyrene has also been doped by Zr(IV), as reported by Samatya et al. [152]. This adsorbent material had the higher fluoride adsorption capacity, 6.14 mg g⁻¹, between pH 2 and 4. The performance of this adsorbent was also studied in packed columns, which showed an optimum fluoride breakthrough capacity of 5.52 mg g⁻¹, with an elution efficiency of 83% by 0.1M NaOH.

830 The wetness impregnation-coprecipitation of a material containing silicon (SiMCM-41) with 831 Cerium (IV) oxide was studied by Xu et al., [153], who reported a fluoride adsorption capacity between 5-6 mmol F g^{-1} at 20 °C and initial fluoride concentration of 2 mmol L⁻¹. Even thorium, a radioactive 832 chemical element, has been used to synthesize a hybrid thorium phosphate composite, Islam et al., [154] 833 that consisted of polycinnamamide thorium (IV) phosphate. The removal of fluoride by this composite 834 835 was 87.6% and the adsorption capacity, calculated from the Langmuir isotherm, was found to be 4.74 mg g^{-1} . The authors explained that the main advantage of the polymeric composite resides in the possibility of 836 837 combining the physical properties of the constituents to obtain new structural or functional properties that 838 can be shaped into any desired form (beads, candles and membranes).

Lanthanum (III) is another element that has been loaded in polymeric matrices, Fang et al. [155]. These authors concluded that the different chemical composition and chemical structure of the polymer matrix play the most important role in fluoride adsorption, and that the strongly acidic adsorbents are more effective on fluoride removal in a neutral pH than weak acidic adsorbents, and finally that in the neutral pH range of 4.5–8.0, the 200CT resin loaded with La would be the most appropriate adsorbent for small amounts of fluoride existing in hot spring water.

Recently, Chen et al., [156] reported the development of a Fe-Al impregnated granular ceramic for fluoride removal from an aqueous solution. It was found that the maximum adsorption capacity was 3.56 mg g⁻¹ according to the Langmuir model, and the adsorption process was explained with the pseudosecond-order and pore diffusion models. The authors found that more than 96% of F⁻ adsorption was performed within 48 h from a 10 mg L⁻¹ initial fluoride solution at pH 7. Also, the presence of CO_3^{2-} and PO_4^{3-} significantly reduced the fluoride removal efficiency. Furthermore, Wu et al., [157] immobilized Fe-

851 Al-Ce on a porous matrix of polyvinyl alcohol (PVA) by crosslinking with boric acid. The 3-5 mm size-852 granules gave high hydraulic conductivity in packed beds for the removal of fluoride from drinking water. 853 The trimetallic oxide and PVA were found to form chemical bonds, which made the oxide heavily loaded 854 in the porous structure of PVA. Moreover, the trimetallic oxide concentration was higher than the PVA 855 concentration (7.5%) which produced a higher adsorption capacity in the granules; achieving an adsorption capacity of fluoride ions of 4.46 mg g^{-1} at pH 6.5, at an initial fluoride concentration of 19 mg 856 L⁻¹. Table 6 shows the fluoride adsorption capacity of some modified synthetic resins, ceramics and 857 858 polymers.

859

860 **3. Final remarks**

861 It is evident that the presence of fluoride in water supplies in many countries around the world is 862 still a problem to be solved. As shown in this review, different processes can be used to remove fluoride from water. However, the adsorption process is generally considered more attractive because of its 863 864 effectiveness, convenience, ease of operation, simplicity of design, and for economic and environmental reasons. Moreover, the improvement of different organic and inorganic adsorbents is progressing with the 865 866 support of nanotechnology and advanced characterization techniques. Metal oxides/hydroxides/oxihydroxides and mixed metal oxides have shown a high potential to remove fluoride 867 from water, however, it is important to consider that the efficiency, selectivity, chemical and physical 868 869 stability, and cost are still drawbacks that have to be improved. Additionally, there is the need to validate 870 through adsorption-desorption cycles the use of the many adsorbent materials, reported in the literature, in 871 continuous systems at laboratory and pilot scale before these materials may be applied in water treatment 872 systems to meet the water regulations. Finally, it is evident that more research is needed to develop 873 adsorbent materials that provide suitable and economical solutions to remove fluoride from water, 874 especially for those communities in third world countries that do not have access to safe drinking water.

875

876 4. Acknowledgments

877 This work was financially supported by grants from CONACYT-Ciencia Basica (SEP-CB-2008-01878 105920 and SEP-CB-2014-237118). Litza H. Velazquez, Esmeralda Vences and Jose L. Flores would like
879 to thank CONACYT for receiving the scholarship. Finally, the authors thank Lucia Aldana N. for the
880 assistance in the English writing of this manuscript.

881

882 **5. References**

883 1. Gosh, A., Mukherjee, K., Gosh S.K., Saha B., 2013. Sources and toxicity of fluoride in the
884 environment, Res. Chem. Intermed. 39, 2881-2915.

- 885 2. Facts about global groundwater usage, compiled by the National Groundwater Association, USA,
- 886 http://www.ngwa.org/Fundamentals/use/Documents/global-groundwater-use-fact-sheet.pdf.
- 887 (Accessed on May 2015).
- 888 3. WHO, Guidelines for drinking water quality, 3rd ed., vol. 1, Recommendations. World Health
 889 Organization, Geneva, 2004.
- 4. Ozsvath, D. L., 2009. Fluoride and environmental health: a review, Rev. Environ. Sci. Technol. 8,
 59-79.
- 892 5. WHO, Guidelines for drinking water quality, 4rd ed. World Health Organization, Geneva, 2011.
- 893 6. UNICEF, 1999. WaterFront, Fluoride in water: an overview, Programme Division, 13 pp. 11-14.
- 894 7. EPA, National Primary Water Regulations in EPA 40 CFR Parts 141-143. Environmental Protection
 895 Agency, USA, 1991.
- 896 8. Onyango, M.S., Matsuda, H., 2006. Fluoride removal from water using adsorption technique, Adv.
 897 Fluorine Sci. 2, 1-48.
- 898 9. Babaeivelni, K., Khodadoust, A.P., 2013. Adsorption of fluoride onto crystalline titanium dioxide:
 899 Effect of pH, ionic strength, and co-existing ions. J. Colloid Interface Sci, 394, 419-427.
- 900 10. Mondal, P., Suja, G. 2015. A review on adsorbents used for defluoridation of drinking water, Rev.
 901 Environ. Sci. Biotechnol., 14, 195-210.
- 902 11. Tomar, V., Kumar, D., 2013. A critical study on efficiency of different materials for fluoride removal
 903 from aqueous media, Chem. Central J. 7, 51-66.
- Bhatnagar, A., Kumar, E., Sillanpaa, M., 2011. Fluoride removal from water by adsorption- a review,
 Chem Eng. J. 171, 811-840.
- 13. Loganathan, P., Vigneswaran, S. Kandasamy J., Naidu, R., 2013. Defluoridtion of drinking water
 using adsorption processes, J. Haz. Mat. 248-249, 1-19.
- Hao, O., Huang, C., 1986. Adsorption Characteristics of Fluoride onto Hydrous Alumina. J. Environ.
 Eng. 112, 1054–1069.
- 910 15. Shen, F., Chen, X., Gao, P., Chen G., 2003. Electrochemical removal of fluoride ions from industrial
 911 wastewater, Chem. Eng. Sci. 58, 987–993.
- 912 16. Mollah, M.Y.A., Schennach, R., Parga, J.R., Cocke, D.L., 2001. Electrocoagulation (EC) science and
 913 applications, J. Hazard. Mater. 84, 29–41.
- 914 17. Chen, G.H., 2004. Electrochemical technologies in wastewater treatment, Sep. Purif. Technol. 38,
 915 11–41.
- 18. Liu, R., Zhu, L., Gong, W., Lan, H., Liu, H., Qu, J., 2013. Effects of fluoride on coagulation
 performance of aluminum chloride towards Kaolin suspension, Colloids and Surfaces A:
 Physicochem. Eng. Aspects 421, 84–90.

- 919 19. Hu, C.Y., Lo, S.L., Kuan, W.H., 2005. Effects of the molar ratio of hydroxide and fluoride to Al(III)
 920 on fluoride removal by coagulation and electrocoagulation, J. Colloid Inter. Sci. 283, 472–476.
- 921 20. Sujana, M.G., Thakur, R.S., Rao, S.B., 1998. Removal of Fluoride from Aqueous Solution by Using
 922 Alum Sludge, J. Colloid Inter. Sci. 206, 94–101.
- 21. Zhu, J., Zhao, H., Ni, J., 2007. Fluoride distribution in electrocoagulation defluoridation process, Sep.
 Purif. Technol. 56, 184–191.
- 22. Hu, C.Y., Lo, S.L., Kuan, W.H., 2007. Simulation the kinetics of fluoride removal by
 electrocoagulation (EC) process using aluminum electrodes, J. Haz. Mat. 145, 180–185.
- 927 23. Gong, W.X., Qu, J.H., Liu, R.P., Lan, H.C., 2012. Effect of aluminum fluoride complexation on
 928 fluoride removal by coagulation, Colloids and Surfaces A: Physicochem. Eng. Aspects, 395, 88–93.
- 929 24. Ayoob, S., Gupta, A.K., Bhat, V.T., 2008. A conceptual overview on sustainable technologies for the
 930 defluoridation of drinking water, Critical Rev. Environ. Sci. Technol. 38, 401-470.
- 25. Arora, M., Maheshwari, R.C., Jain, S.K., Gupta, A., 2004. Use of membrane technology for potable
 water production, Desalination 170, 105-112.
- 933 26. Ndiaye, P.I., Moulin, P., Dominguez, L., Millet, J.C., Charbit, F., 2005. Removal of fluoride from
 934 electronic industrial effluent by RO membrane separation, Desalination 173, 25-32.
- 935 27. Nicolas, S., Guihard, L., Marchand, A., Bariou, B., Amrane, A., Mazighi, A., Mameri N., El
 936 Midaoui, A., 2010. Defluoridation of backish northern Sahara groundwater-Activity product
 937 calculations in order to optimize pretreatment before reverse osmosis, Desalination 256, 9-15.
- 938 28. Peinemann, K.V., Nunes, S. P., 2011. Membrane Technology, Volume 1: Membranes for Life
 939 Sciences. John Wiley & Sons, pp. 157.
- 940 29. Hichour, M., Persin, F., Sandeaux, J., Gaavach, C. 2000. Fluoride removal from waters by Donnan
 941 dialysis, Sep. Purif. Technol. 18, 1-11.
- 30. Lounici, H., Adour, L., Belhocine, D., Elmidaoui, A., Barriou, B., Mameru, N., 2001. Novel
 technique to regenerate activated alumina bed saturated by fluoride ions, Chem. Eng. J. 81, 153-160.
- 944 31. Germes, H., Persin, F., Sandeaux, J., Pourcelly, G., Mountadar, M., 2002. Defluoridation of
 945 groundwater by a hybrid process combining adsorption and Donnan dialysis, Desalination 145, 287946 291.
- 947 32. Annouar, S., Mountadar, M., Soufiane, A., Elmidaoui, A., Sahli, M.A.M, Menkouchi, A., 2004.
 948 Defluoridation of underground water by adsorption on the chitosan and by electrodialysis,
 949 Desalination 165, 437-438.
- 33. Sahli, M.A.M., Annouar, S., Tahaikt, M., Mountadar, M., Soufiane, A., Elmidaoui, A. 2007. Fluoride
 removal for underground backish water by adsorption on the natural chitosan and by electrodialysis,
 Desalination 212, 37-45.

- 953 34. Elazhar, F., Tahaikt, M., Zouahri, A., Taky, M., Hafsi, M., Elmidaoui, A. 2013. Defluoridation of
 954 Moroccan Groundwater by nanofiltration and electrodialysis: performance and cost comparison,
 955 World Appl. Sci. J. 22, 844-850.
- 35. Mohapatra, M., Anand, S., Mishra, B.K., Giles, D.E., Singh, P., 2009. Review of fluoride removal
 from drinking water, J. Environ. Man. 91, 67-77.
- 958 36. Elazhar, F., Tahaikt, M., Achatei, A., Elmidaoui, F., Taky, M., Hannouni, F.E. Laaziz, I., Jariri, S.,
 959 Amrani, M.E., Elmidaoui, A., 2009. Economical evaluation of the fluoride removal by nanofiltration,
 960 Desalination 24, 154-157.
- 37. Nasr, A.B., Charcosset, C., Amar, R.B., Walha, K., 2013. Defluoridation of water by nanofiltration, J.
 Fluorine Chem. 150, 92-97.
- 38. Ku, Y., Chiou, H.M., Wang, W., 2002. The removal of fluoride ion from aqueous solution by a cation
 synthetic resin. Sep. Sci. Technol. 37, 89-103.
- 39. Singh, K., Lataye, D.H., Wasewar, K.L., Yoo, C.K., 2013. Removal of fluoride from aqueous solution: status and techniques, Desalination and Water Treatment 51, 3233-3247.
- 967 40. Oyango, M.S., Kojima, Y., Aoyi, O., Bernardo, E.C., Mastuda H., 2004. Adsorption equilibrium
 968 modeling and solution chemistry dependence of fluoride removal from water by trivalent-cation969 exchanged zeolite F-9, J. Colloid Inter. Sci. 279, 341-350.
- 970 41. Pan, B., Xu, J., Wu, B., Li, Z., Liu, X., 2013. Enhanced removal of fluoride by polystyrene anion
 971 exchanger supported hydrous zirconium oxide nanoparticles, Environ. Sci. Technol. 47, 9347-9354.
- 42. Viswanathan, N., Meenakshi, S., 2009. Role of metal ion incorporation in ion exchange resin on the
 selectivity of fluoride, J. Hazard. Mater. 162, 920-930.
- 43. Fan, X. Parker, D.J., Smith M.D., 2003. Adsorption kinetics of fluoride on low cost materials. Water
 Res. 37, 4929–4937.
- 976 44. Pervov, A.G., Dudkin, E.V., Sidorenko, O.A., Antipov, V.V., Khakhanov, A., Makarov, R.I., 2000.
 977 RO and NF membrane systems for drinking water production and their maintenance techniques,
 978 Desalination, 132, 315-321.
- 45. Habuda-Stanić, M., Ravančić, M.E., Flanagan, A. 2014. A review on adsorption of fluoride from
 aqueous solution, Materials 7, 6317-6366.
- 46. Li, Y.H., Wang, S., Cao, A., Zhao, D., Zhang, X., Xu, C., Luan, Z., Ruan, D., Liang, J., Wu, D., Wei,
 B., 2001. Adsorption of fluoride from water by amorphous alumina supported on carbon nanotubes,
 Chem. Phys. Lett. 350, 412–416.
- 47. Ghorai, S., Pant, K.K., 2004. Investigations on the column performance of fluoride adsorption by
 activated alumina in a fixed-bed, Chem. Eng. J. 98, 165-173.

- 48. Leyva Ramos, R., Ovalle-Turrubiartes, J., Sanchez-Castillo, M.A., 1999. Adsorption of fluoride from
 aqueous solution on aluminum-impregnated carbon. Carbon 37, 609-617.
- 49. Srimurali, M., Pragathi, A., Karthikeyan, J., 1998. A study on removal of fluoride from drinking
 water by adsorption onto low-cost materials, Environ. Pollut. 99, 285–289.
- 990 50. Reardon, E.J., Wang, Y., 2001. Activation and regeneration of a soil sorbent for defluoridation of
 991 drinking water, Appl. Geochem. 16, 531–539.
- 51. Mahramanlioglu, M., Kizilcikli, I., Bicer, I.O., 2002. Adsorption of fluoride from aqueous solution by
 acid treated spent bleaching earth, J. Fluorine Chem.115, 41–7.
- 52. Raichur, A.M., Basu, M.J., 2001. Adsorption of fluoride onto mixed rare earth oxides, Sep. Purif.
 Technol. 24, 121–127.
- 53. McKee, R.H., 1934. Removal of fluoride from drinking water. Ind. Eng. Chem. 26, 849–50.
- 54. Islam, M., Patel, R. K., 2007. Evaluation of removal efficiency of fluoride from aqueous solution
 using quick lime. J. Hazard. Mat. 143, 303-310.
- 999 55. Nath, S.K., Dutta R.K., 2012. Acid-enhanced limestone defluoridation in column reactor using oxalic
 acid, Process Saf. Environ. Prot. 90, 65-75.
- 56. Badillo-Almaraz, V. E., Flores, J.A., Arriola, H., López F.A., Ruiz-Ramirez, L., 2007. Elimination of
 fluoride ions in water for human consumption using hydroxyapatite as an adsorbent, J. Radioanal.
 Nucl. Chem. 271, 741-744.
- 57. Gao, S., Sun R., Wei, Z., Zhao, H., Li, H., Hu, F., 2009. Size-dependent defluoridation properties of
 synthetic hydroxyapatite, J. Fluorine Chem. 130, 550-556.
- 1006 58. Poinern, G.E.J., Ghosh, M.K., Ng, Y.J., Issa, T.B., Anand, S., Singh, P., 2011. Defluoridation
 1007 behavior of nanostructured hydroxyapatite synthesized through an ultrasonic and microwave
 1008 combined technique, J. Hazard. Mater. 185, 29-37.
- 59. Wang, Y., Chen, N., Wei W., Cui, J., Wei, Z., 2011. Enhanced adsorption of fluoride from aqueous
 solution onto nanosized hydroxyapatite by low-molecular-weight organic acids, Desalination 276,
 161-168.
- 1012 60. Nagappa, B., Chandrappa, G.T., 2007. Mesoporous nanocrystalline magnesium oxide for
 1013 environmental remediation, Microporous Mesoporous Mater. 106, 212-218.
- Maliyekkal, S.M., Antony, K.R., Pradeep, T., 2010. High yield combustion synthesis of
 nanomagnesia and its applications for fluoride removal, Sci. Total Envion. 408, 2273-2282.
- Sasaki, K., Fukumoto, N., Moriyama S., Hirajima T., 2011. Sorption characteristics of fluoride on to
 magnesium oxide-rich phases calcined at different temperatures, J. Hazard. Mater. 191. 240-248.
- 1018 63. Na, C.K., Park, H.J., 2010. Defluoridation from aqueous solution by lanthanum hydroxide, J. Hazard.
- 1019 Mater. 183, 512-520.

- 1020 64. Rao, C.R.N., Karthikeyan, J., 2012. Removal of fluoride from water by adsorption onto lanthanum
 1021 oxide, Water Air Soil Pollut. 223, 1101-1114.
- 1022 65. Tang, Y., Wang, J., Gao1, N., 2010. Characteristics and model studies for fluoride and arsenic
 1023 adsorption on goethite, J. Environmental Sci. 22, 1689-1694.
- Kumar, E., Bhatnagar A., Ji, M., Jung, W., Lee, S.H., Kim, S.J., Lee G., Song, H., Choi, J.Y., Yang,
 J.S., Jeon, B.H., 2009. Defluoridation from aqueous solutions by granular ferric hydroxide (GFH),
 Water Res. 43, 490-498.
- Tang, Y., Guan, X., Wang, J., Gao, N., McPhail, M.R., Chusuei, C.C., 2009. Fluoride adsorption onto
 granular ferric hydroxide: Effects of ionic strength, pH, surface loading, and major co-existing
 anions, J. Hazard. Mater. 171, 774-779.
- 1030 68. Mohapatra, M., Rout, K., Singh, P., Anand, S., Layek, S., Verma, H.C., Mishra, B.K., 2011. Fluoride
 1031 adsorption studies on mixed-phase nano iron oxides prepared by surfactant mediation-precipitation
 1032 technique, J. Hazard. Mater. 186, 1751-1757.
- 1033 69. Dou, X., Mohan, D., Pittman, C.U., Yang, Jr.S., Yang, S., 2012. Remediating fluoride from water
 1034 using hydrous zirconium oxide, Chem. Eng. J. 198-199, 236-245.
- 1035 70. Swain, S.K., Patnaik, T., Singh, V,K., Jha, Usha, Patel, R.K., Dey, R.K., 2011. Kinetics, equilibrium
 1036 and thermodynamic aspects of removal of fluoride from drinking water using meso-structured
 1037 zirconium phosphate, Chem. Eng. J. 171, 1218-1226.
- 1038 71. Wajima, T., Umeta, Y., Narita, S., Sugawara, K., 2009. Adsorption behavior of fluoride ions using a
 1039 titanium hydroxide-derived adsorbent, Desalination 249, 323-330.
- 1040 72. Gong, W.X., Qu, J.H., Liu, R.P., Lan, H.C., 2012. Adsorption of fluoride onto different types of
 1041 aluminas, Chem. Eng. J. 189-190, 126-133.
- 1042 73. Goswami, A., Purkait, M.K., 2012. The defluoridation of water by acidic alumina, Chem. Eng. Res.
 1043 Des, 90, 2316–2324.
- Kamble, S.P., Deshpande, G., Barve, P.P., Rayalu, S., Labhsetwar, N.K., Malyshew, A., Kulkarni,
 B.D., 2010. Adsorption of fluoride from aqueous solution by alumina of alkoxide nature: Batch and
 continuous operation, Desalination 264, 15-23.
- 1047 75. Kumar, E., Bhatnagar, A., Kumar, U., Sillanpää, M., 2011. Defluoridation from aqueous solutions by
 1048 nano-alumina: Characterization and sorption studies, J. Hazard. Mater. 186, 1042-1049.
- 1049 76. Liu, R., Gong, W., Lan, H., Gao, Y., Liu H., Qu, J., 2011. Defluoridation by freshly prepared
 1050 aluminum hydroxides, Chem. Eng. J. 175, 144-149.
- 1051 77. Mulugeta, E., Zewge, F., Johnson C.A., Chandravanish, B.S., 2014. A high-capacity aluminum
 1052 hydroxide-based adsorbent for water defluoridation, Desalination and Water Treatment, 52, 54221053 5429.

- 1054 78. Wang, S.G, Ma, Y., Shi, Y.J., Gong, W.X., 2009. Defluoridation performance and mechanism of
 1055 nano-scale aluminum oxide hydroxide in aqueous solution, J. Chem. Technol. Biotechnol. 84, 10431056 1050.
- 1057 79. Srivastav, A.L., Singh, P.K., Srivastava V., Sharma Y.C., 2013. Application of a new adsorbent for
 1058 fluoride removal from aqueous solutions, J. Hazard. Mater. 263, 342-352.
- 1059 80. Liu, H., Deng, S., Li, Z., Yu, G., Huang, J., 2010. Preparation of Al-Ce hybrid adsorbent and its
 1060 application for defluoridation of drinking water, J. Haz. Mat. 179, 424-430.
- 1061 81. Maliyekkal, S.M., Sharma, A.K., Philip, L., 2006. Manganese-oxide coated alumina: a promising
 1062 sorbent for defluoridation of water, Water Res. 20, 3497-3506.
- 1063 82. Tripathy, S.S., Raichur, A.M., 2008. Abatement of fluoride from water using manganese dioxide1064 coated activated alumina, J. Haz. Mat. 153, 1043-1051.
- 1065 83. Bansiwal, A., Pillewan, P., Biniwale, R.B., Rayalu, S.S., 2010. Copper oxide incorporated
 1066 mesoporous alumina for defluoridation of drinking water, Microporous Mesoporous Mater. 129, 541067 61.
- 1068 84. Deng, S., Liu, H., Zhou, J., Huang, J., Yu, G., 2011. Mn-Ce oxide as a high-capacity adsorbent for
 1069 fluoride removal from water, J. Haz. Mat. 186, 1360-1366.
- 1070 85. Lin, C., He, B.Y., He, S. Wang, T.J., Su, C., Jin, Y., 2012. Fe-Ti oxide nano-adsorbent synthesized
 1071 by co-precipitation for fluoride removal from drinking water and its adsorption mechanism, Powder
 1072 Technol. 227, 3-8.
- 1073 86. Biswas, K., Gupta, K., Ghosh, U.C., 2009. Adsorption of fluoride by hydrous iron(III)-tin(IV)
 1074 bimetal mixed oxide from the aqueous solutions, Chem. Eng. J. 149, 196-206.
- 1075 87. Biswas, K., Bandhoyapadhyay, D., Ghosh, U.C., 2007. Adsorption kinetics of fluoride on iron(III)1076 zirconium(IV) hybrid oxide, Adsorption, 13, 83-94.
- 1077 88. Dou, X., Zhang, Y., Wang, H., Wang, T., Wang, Y., 2011. Performance of granular zirconium-iron
 1078 oxide in the removal of fluoride from drinking water, Water Res. 45, 3571-3578.
- 1079 89. Zhijian, L.I., Deng, S., Zhang, X., Zhou, W., Huang, J., Yu, G., 2010. Removal of fluoride from
 1080 water using titanium-based adsorbents, Front. Environ. Sci. Engin. China 4, 414-420.
- 1081 90. Lin, C., He, S.B.Y., Wang, T.J., Su, C.L., Zhang, C., Yong, J., 2012. Synthesis of iron-doped
 1082 titanium oxide nanoadsorbent and its adsorption characteristics for fluoride in drinking water, Ind.
 1083 Eng. Chem. Res. 51, 13150-13156.
- 1084 91. Biswas, K., Saha, S.K., Ghosh, U.C., 2007. Adsorption of fluoride from aqueous solution by a
 1085 synthetic Iron(III)-Aluminium(III) mixed oxides, Ind. Eng. Chem. Res. 46, 5346-5356.
- 1086 92. Zhao, X., Wang, J., Wu, F., Wang, F., Cai, Y., Shi, Y., Jiang, G., 2010. Removal of fluoride from aqueous media by Fe₃O₄@Al(OH₃) magnetic nanoparticles, J. Haz. Mat. 173, 102-109.

- 1088 93. Chai, L., Wang, Y., Zhao, N., Yang, W., You, X., 2013. Sulfate-doped Fe₃O₄/Al₂O₃ as a novel adsorbent for fluoride removal from drinking water, Water Res. 47, 4040-4049.
- 1090 94. Kim, J.H., Lee, C.G., Park, J.A., Kang, J.K., Yoon, S.Y., Kim, S.B., 2013. Fluoride removal using
 1091 calcinated Mg/Al layered double hydroxides at high fluoride concentration, Water Sci. Technol.
 1092 Water Suppl. 1, 249-256.
- 1093 95. Kang, D., Yu, X., Tong, S., Ge, M., Zuo, J., Cao, C., Song, W., 2013. Performance and mechanism of
 1094 Mg/Fe layered double hydroxides for fluoride and arsenate removal from aqueous solution. Chem.
 1095 Eng. J. 228, 731-740.
- 1096 96. Luv, L., He, J., Wei, M., Evans, D.G., Zhou, Z., 2007. Treatment of high fluoride concentration water
 1097 by MgAl-CO₃ layered double hydroxides: kinetic and equilibrium studies, Water Res. 41, 1534-1542.
- 1098 97. Batistella, L., Venquiaruto, L.D., Di Luccio, M., Oliveira, J.V., Pergher, S.B.C., Mazutti, M.A., de
 1099 Oliveira, D., Mossi ,A.J., Treichel, H., Dallago, R., 2011. Evaluation of acid activation under the
 adsorption capacity of double layered hydroxides of Mg-Al CO₃ type for fluoride removal from
 aqueous medium. Ind. Eng. Chem. Res. 50, 6871-6876.
- 1102 98. Zhang, T., Li, Q., Xiao, H., Mei, Z., Lu, H., Zhou, Y., 2013. Enhanced fluoride removal from water
 1103 by non-thermal plasma modified CeO₂/Mg-Fe layered double hydroxides, Appl. Clay Sci. 72, 1171104 123.
- 1105 99. Zhang, T., Li, Q., Xiao, H., Mei, Z., Lu, H., Zhou, Y., 2012. Synthesis of Li-Al layered hydroxide
 (LDHs) for efficient fluoride removal, Ind. Eng. Chem. Res. 51, 11490-11498.
- 100. Dey, S., Goswami, S., Gosh, U.C. 2004. Hydrous ferrix oxide (HFO)-A scavenger for fluoride from
 contaminated water, Water Air Soil Poll. 158, 311-323.
- 1109 101. Wu, X., Zhang, Y., Dou, X., Yang, M., 2007. Fluoride removal performance of a novel Fe–Al–Ce
 1110 trimetal oxide adsorbent. Chemosphere 69, 1758–1764.
- 102. Wu, X., Zhang, Y., Dou, X., Zhao, B., Yang, M., 2013. Fluoride adsorption on an Fe–Al–Ce trimetal
 hydrous oxide: Characterization of adsorption sites and adsorbed fluorine complex species. Chem.
 Eng, J. 223, 364–370.
- 103. Biswas, K., Gupta, K., Goswami, A., Ghosh, U.C., 2010. Fluoride removal efficiency from aqueous
 solution by synthetic iron(III)–aluminum (III)–chromium(III) ternary mixed oxide. Desalination 255,
 44–51.
- 1117 104. Sivasankar, V., Murugesh, S., Rajkumar, S., Darchen, A., 2013. Cerium dispersed in carbon (CeDC)
 1118 and its adsorption behavior: A first example of tailored adsorbent for fluoride removal from drinking
 1119 water. Chem. Engine J. 214, 45-54.

- 105. Hernández-Montoya, V., Ramírez-Montoya, L.A., Bonilla-Petriciolet, A., Móntes-Duran M.A., 2012.
 Optimizing the removal of fluoride from water using new carbons obtained by modification of nut
 shell with a calcium solution from egg shell, Biochem. Eng. J. 62, 1-7.
- 106. Tchomgui-Kamga, E., Alonzo, V., Nanseu-Nijiki, C.P., Audebrand, N., Ngameni, E., Darchen, A.
 2010. Preparation and characterization of charcoals that contain dispersed aluminium oxide as
 adsorbent for removal from drinking water, Carbon 48, 333-343.
- 107. Ma, Y., Wang S.G., Fan, M., Gong, W.X., Gao B.Y.. 2009. Characteristics and defluoridation
 performance of granular activated carbons coated with manganese oxides, J. Hazard. Mater. 168,
 1128 1140-1146.
- 108. Janardhana, C., Rao, G.N., Sathish, R.S., Kumar, P.S., Kumar, V.A., Madhav, M.V., 2007. Study on
 defluoridation of drinking water using zirconium ion impregnated activated charcoals Indian J.
 Chem. Technol. 14, 350–354.
- 109. Sathish, R.S., Sairam, S., Raja, V.G., Rao, G.N., Janardhana C., 2008. Defluoridation of water using
 zirconium impregnated coconut fiber carbon, Sep. Purif. Technol. 43, 3676-3694.
- 1134 110. Alagumuthu, G., Rajan, M., 2010. Equilibrium and kinetics of adsorption of fluoride onto zirconium
 1135 impregnated cashew nut shell carbon. Chem. Eng. J. 158, 451-457.
- 1136 111. Li, Y., Du, Q., Wang, J., Liu, T., Sun, J., Wang, Y., Wang Z., Xia, Y., Xia, L., 2013. Defluoridation
 1137 from aqueous solution by manganese oxide coated graphene oxide, J. Fluorine Chem. 148, 67-73.
- 1138 112. Velazquez-Jimenez, L.H., Hurt, R.H., Matos, J., Rangel-Mendez, J.R., 2014. Zirconium-carbon
 hybrid sorbent for removal of fluoride from water: oxalic acid mediated Zr(IV) assembly and
 adsorption, Eviron. Sci. Technol. 48, 1166-1174.
- 1141 113. Gupta, R. Ahuja, P., Khan, S., Saxena, R.K., Mohapatra, H., 2000. Microbial biosorbents: meeting
 1142 challenges of heavy metal pollution in aqueous solutions, Curr. Sci., 78, 967–973.
- 1143 114. Mehta, S.K., Gaur, J.P., 2001. Characterization and optimization of Ni and Cu sorption from aqueous
 1144 solution by *Chlorella vulgaris*, Ecol. Eng. 18, 1–13.
- 1145 115. Ilhami, T., Gulay, B., Emine, Y., Gokben, B., 2005. Equilibrium and kinetic studies on biosorption of
 Hg (II), Cd (II) and Pb (II) ions onto micro algae *Chlamydomonas reinhardtii*, J. Environ. Manage.
 1147 77, 85–92.
- 1148 116. Crist, R.H., Oberholser, K., Shank, N., Nguyen, M., 1981. Nature of binding between metallic ions
 and algal cell walls, Environ. Sci. Technol. 15, 1212–1217.
- 1150 117. Hunt, S., Eccles, H. Diversity of Bio Polymers Structure and its Potential for Ion-Bonding
 1151 Applications, Immobilization of Ions by Biosorption, Ellies Horword, Chichester (1986), pp. 15–46.
- 1152 118. Mohan, S.V., Karthikeyan, J., 2000. Removal of diazo dye from aqueous phase by algae spirogyra
 1153 species, Toxicol. Environ. Chem. 74, 147–154.

- 1154 119. Mohan, S.V., Ramanaiah, S.V., Rajkumar, B., Sarma, P.N., 2007. Biosorption of fluoride from
 aqueous phase onto Algal *Spirogyra* sp. and evaluation of adsorption kinetics, Bioresour. Technol.
 1156 98, 1006–1011.
- 1157 120. Mohan, S.V., Ramanaiah, S.V., Rajkumar, B., Sarma, P.N., 2007. Removal of fluoride from aqueous
 phase by biosorption onto algal biosorbent *Spirogyra* Sp. I02: sorption mechanism elucidation, J.
 Hazard. Mater. 141, 465–474.
- 1160 121. Mohan, S.V., Bhaskar, Y.V., Karthikeyan, J., 2003. Biological decolorization of simulated azo dye in
 1161 aqueous phase by algae Spirogyra species, Int. J. Environ. Pollut. 21, 211–222.
- 1162 122. Mohan, S.V., Karthikeyan, J., 2000. Removal of diazo dye from aqueous phase by algae spirogyra
 1163 species, Toxicol. Environ. Chem., 74, 147–154.
- 1164 123. Jamode, B., Chandak, S., Rao, M., 2004. Evaluation of performance and kinetic parameters for
 1165 defluoridating using *Azadirachta Indica* (Neem) leaves as low cost adsorbents, Pollut. Res., 23, 239–
 1166 250.
- 1167 124. Yao, R., Meng, F., Zhang, L., Ma, D., Wang, M., 2009. Defluoridation of water using neodymium1168 modified chitosan, J. Hazard. Mater. 165, 454–460.
- 1169 125. Sundaram, C.S., Viswanathan, N., Meenakshi, S., 2008. Uptake of fluoride by nano1170 hydroxyapatite/chitosan, a bioinorganic composite, Bioresour. Technol. 99, 8226–8230.
- 1171 126. Sundaram, C.S., Viswanathan, N., Meenakshi, S., 2009. Defluoridation of water using
 1172 magnesia/chitosan composite, J. Hazard. Mater. 163, 618-624.
- 1173 127. Sundaram, C.S., Viswanathan, N., Meenakshi, S., 2009. Fluoride sorption by nano1174 hydroxyapatite/chitin composite, J. Hazard. Mater. 172, 147-151.
- 1175 128. Jagtap, S., Thakre, D., Wanjari, S., Kamble, S., Labhsetwar, N., Rayalu, S., 2009. New modified
 1176 chitosan-based adsorbent for defluoridation of water, J. Colloid Interface Sci. 332, 280–290.
- 1177 129. Kamble, S.P., Jagtap, S., Labhsetwar, N.K., Thakare, D., Godfrey, S., Devotta, S., Rayalu, S.S., 2007.
 1178 Defluoridation of drinking water using chitin, chitosan and lanthanum-modified chitosan, Chem. Eng.
 1179 J. 129, 173–180.
- 1180 130. Bansiwal, A., Thakre, D., Labhshetwar, N., Meshram, S., Rayalu, S., 2009. Fluoride removal using
 1181 lanthanum incorporated chitosan beads, Colloids Surf., B: Biointerfaces 74, 216–224.
- 1182 131. Thakre, D., Jagtap, S., Bansiwal A., Labhsetwar, N., Rayalu, S., 2010. Synthesis of La-incorporated
 1183 chitosan beads for fluoride removal from water, J. Fluorine Chem. 131, 373-377.
- 1184 132. Jagtap, S., Yenkie M.K., Das, S., Rayalu, S., 2011. Synthesis and characterization of lanthanum
 1185 impregnated chitosan flakes for fluoride removal in water, Desalination 273, 267-275.
- 1186 133. Viswanathan, N., Meenakshi, S., 2008. Enhanced fluoride sorption using La(III) incorporated
 1187 carboxylated chitosan beads, J. Colloid Interface Sci. 322, 375-383.

- 1188 134. Viswanathan, N., Meenakshi, S., 2009. Synthesis of Zr(IV) entrapped chitosan polymeric matrix for
 1189 selective fluoride sorption, Colloids Surf. B: Biointerfaces 72, 88-93.
- 1190 135. Liu, B., Wang D., Yu, G., Meng, X., 2013. Removal of F⁻ from aqueous solution using Zr(IV)
 1191 impregnated dithiocarbamate modified chitosan beads, Chem. Eng. J. 228, 224-231.
- 1192 136. Swain, S. K., Dey R.K., Islam M., Patel, R.K., Jha, U, Patnaik, T., Airoldi, C., 2009. Removal of
 Fluoride from Aqueous Solution Using Aluminum-Impregnated Chitosan Biopolymer, Sep. Sci.
 Technol. 44, 2096-2116.
- 1195 137. Viswanathan, N., Meenakshi, S., 2010. Enriched fluoride sorption using alumina/chitosan composite,
 1196 J. Hazard. Mater. 178, 226-232.
- 1197 138. Ramanaiah, S.V., Mohan, S.V., Sarma, P.N., 2007. Adsorptive removal of fluoride from aqueous
 phase using waste fungus (Pleurotus ostreatus 1804) biosorbent: Kinetics evaluation, Ecol Eng. 31,
 1199 47–56.
- 1200 139. Yu, X., Tong, S., Ge, M., Zuo, J., 2013. Removal of fluoride from drinking water by
 1201 cellulose@hydroxyapatite nanocomposites, Carbohydr. Polym. 92, 269-275.
- 140. Zhao, Y., Li, X., Liu, L., Chen, F., 2008. Fluoride removal by Fe(III)-loaded ligand exchange cotton
 cellulose adsorbent from drinking water, Carbohydr. Polym. 72, 144-150.
- 141. Suzuki, T., Nakamura, A., Niinae M., Nakata, H., Fujii, H., Tasaka, Y., 2013. Immobilization of
 fluoride in artificially contaminated kaolinite by the addition of commercial-grade magnesium oxide,
 Chem. Eng. J. 233, 176-184.
- 142. Xu, X., Li, Q., Cui, H., Pang, J., Sun, L., An, H., Zhai, J., 2011. Adsorption of fluoride from aqueous
 solution on magnesia-loaded fly ash cenospheres, Desalination 272, 233-239.
- 143. Paudyal, H., Pangeni, B., Inoue, K., Kawakita, H., Ohto, K., Alam, S., 2013. Adsorptive removal of
 fluoride from aqueous medium using a fixed bed column packed with Zr(IV) loaded dried orange
 juice residue, Biores. Technol. 146, 713-720.
- 144. Paudyal, H., Pangeni, B., Ghimire, K.N., Inoue, K., Ohto, K., Kawakita, H., Alam, S., 2012.
 Adsorption behavior of orange waste gel for some rare earth ions and its application to the removal of fluoride from water, Chem. Eng. J. 195-196, 289-296.
- 1215 145. Ganvir, V., Das, K., 2011. Removal of fluoride from drinking water using aluminum hydroxide
 1216 coated rice husk ash, J. Haz. Mater. 185, 1287-1294.
- 1217 146. Wang, X.H., Song, R.H., Yang, H.C., Shi, Y.J., Dang, G.B., Yang, S., Zhao, Y., Sun, X.F., Wang,
 1218 S.G., 2013. Fluoride adsorption on carboxylated aerobic granules containing Ce(III), Biores. Technol.
 1219 127, 106-111.
- 147. Sujana, M.G., Mishra, A., Acharya, B.C., 2013. Hydrous ferric oxide doped alginate beads for
 fluoride removal: adsorption kinetics and equilibrium studies, Appl. Surf. Sci. 270, 767-776.

- 1222 148. Huo, Y., Ding, W., Huang, X., Xu, J., Zhao, M., 2011. Fluoride Removal by Lanthanum Alginate
- 1223 Bead: Adsorbent Characterization and Adsorption Mechanism, Chin. J. Chem. Eng. 19, 365-370.
- 149. Zhou, Y., Yu, C., Shan, Y., 2004. Adsorption of fluoride from aqueous solution on La³⁺-impregnated
 cross-linked gelatin, Sep. Purif. Technol. 36, 89-94.
- 1226 150. Chen, N., Zhang, Z., Feng, C., Li, M., Zhu, D., Sugiura, N., 2011. Studies on fluoride adsorption of
 iron impregnated granular ceramics from aqueous solution, Mater. Chem. Phys. 125, 293-298.
- 1228 151. Swain, S.K., Mishra, S., Patnaik, T., Patel, R.K., Jha, U., Dey, R.K., 2012. Fluoride removal 1229 performance of a new hybrid sorbent of Zr(IV)–ethylenediamine, Chem. Eng. J. 184, 72-81.
- 1230 152. Samatya, S., Mizuki, H., Io, Y., Kawakita, H., Uezu, K., 2010. The effect of polystyrene as a porogen
 1231 on the fluoride ion adsorption of Zr(IV) surface-immobilized resin, React. Funct. Polym. 70, 63-68.
- 1232 153. Xu, Y.M., Ning, AR., Zhao, J., 2001. Preparation and Defluorination Performance of Activated
 1233 Cerium(IV) Oxide/SiMCM-41 Adsorbent in Water, J. Colloid Interface Sci. 235, 66-69.
- 1234 154. Islam, M., Mishra, P. C., Patel, R., 2011. Fluoride adsorption from aqueous solution by a hybrid
 thorium phosphate composite, Chem. Eng. J. 166, 978-985.
- 1236 155. Fang, L., Ghimire K.N., Kuriyama, M., Ioue, K., Makino, K., 2003. Removal of fluoride using some
 1237 lanthanum(III)-loaded adsorbents with different functional groups and polymer matrices, J. Chem.
 1238 Technol. Biotechnol. 78, 1038-1047.
- 1239 156. Chen, N., Feng, C., Li, M., 2014. Fluoride removal on Fe-Al-impregnated granular ceramic adsorbent
 1240 from aqueous solution, Clean Technol. Environ. Policy. 16, 609-617.
- 1241 157. Wu, H.-X., Wang, T.-J., Chen, L., Jin, Y., Zhang, Y., & Dou, X.-M., 2011. Granulation of Fe–Al–Ce
 hydroxide nano-adsorbent by immobilization in porous polyvinyl alcohol for fluoride removal in
- 1243 drinking water. Powder Technology, 209(1–3), 92–97.

Technology	Advantages	Disadvantages
Coagulation/Precipitation	Widely used, high efficiency, commercially available technique	Could be expensive due to the large amounts of chemical required, efficiency depends of pH and presence of co-ions in water to be treat, adjustment and readjustment of pH is required. Formation of toxic sludge that requires it disposal. Low effectiveness (cannot remove F below 5 mg L^{-1}).
Membrane processes: reverse osmosis, nanofiltration	High efficiency, remove other contaminants. No chemicals required.	High capital investment due to the operational (energy) and maintenance cost. Toxic waste water is produced due to F concentrated residue. No ion selectively. Some membranes are pH sensitive. Clogging, scaling and fouling problems.
Electrochemical treatments: dialysis, electrodialysis	High efficiency and selectivity. No chemical required. No waste production	High cost during installation, operation (energy) and maintenance. No ion selectivity. Skilled labor required. Polarization problems.
Ion exchange	High efficiency, simplicity and flexibility of design,	Expensive due to the resins, vulnerable to interfering ions (sulfate, phosphate, chloride, bicarbonate, etc.). Replacement of media after multiple regenerations, produces toxic liquid waste, and the efficiency is highly pH-dependent.
Adsorption	Greater accessibility and low cost due to the wide range of adsorbents, simple operation.	High efficiency often demands adjustment and readjustment of pH, some water ions can interfere in fluoride adsorption. Replacement of media after multiple regenerations. Disposal of used adsorbent.
U		

Table 1. Summary of the most common water treatment technologies for fluoride removal [8, 13,45].

Lanthanum hudrovida	capacity/ mg g ⁻¹	Optimal pH	Temperature/°C	Reference
	242.2	7.5	25	[63]
Granular ferric hydroxide	7.0	4-8	25	[66]
Zirconium oxide	68	7	25	[69]
Alumina hydroxide	110	5.0-7.2	25	[76]
Nano-AlOOH	3.26	7	Carr	[78]

Table 2. Adsorption capacities and other parameters for the removal of fluoride by selected monometallic adsorbents.

Adsorbent	Fluoride adsorption capacity/ mg g ⁻¹	Optimal pH	Temperature/°C	Reference
Al-based material modified with Ce	62	6	25	[80]
Al-Mn hybrid material	2.852	4-7	30	[81]
MnO ₂	0.16	7	25	[82]
Powder Mn-Ce material mixed with pseudo- bohemite (AlOOH)	79.5	6	25	[84]
Hydrous Fe(III)-Zr(IV) hybrid oxide	7.51	6.8	20	[87]
Iron doped Ti(IV)	53.22	7	25	[90]
Fe(III)-Al(III)	17.73	6.9	28	[91]
Fe ₂ O ₃ /Al(OH) ₃ nanoparticles	88.49	6.5	25	[92]
Sulfate doped Fe ₂ O ₃ /Al(OH) ₃	70.4	7	25	[93]
MgAl-CO ₃	319.8	6	30	[96]
CeO ₂ /Mg-Fe layered double hydroxide composite	52.4	6-7	25	[98]
Li-Al double hydroxide composite	42.43	7	40	[99]
Synthetic hydrated iron(III)-aluminum(III)- chromium(III) ternary mixed oxide	31.88	4-7	30	[103]

Table 3. Adsorption capacities and other parameters for the removal of fluoride by selected multimetallic impregnated adsorbents.

Adsorbent	Fluoride adsorption capacity/ mg g ⁻¹	Optimal pH	Temperature/°C	Reference
Cerium dispersed in carbon	52	8	25	[104]
CMPNS-4	2.3	7	30	[105]
Al-Fe impregnated activated carbon	13.64	7	28 ± 2	[106]
Granular activated carbons coated with manganese oxides	2.24	5.2	28	[107]
Zirconium impregnated coconut fiber carbon	20.109	8	rt*	[109]
Zirconium impregnated cashew nut shell carbon	1.83	7	30	[110]
Manganese oxide coated graphene oxide	11.93	5.5-6.7		[111]
Zirconium-carbon hybrid sorbent	5.94	7	25	[110]
*room temperature				

Table 4. Adsorption capacities and other parameters for the removal of fluoride by carbon based adsorbents.

Adsorbent	Fluoride adsorption capacity/ mg g ⁻¹	Optimal pH	Temperature/°C	Reference
neodymium-modified				
chitosan	22.38	7	50	[124]
Nano- hydroxyapatite/chitosan	1.56	7	30	[125]
Magnesia/chitosan composite	11.236	10.1-10.4	30	[126]
Magnesia/chitin composite	2.840	7	30	[127]
Modified chitosan-based adsorbent	9.0	7.03	30±2	[128]
Lanthanum-modified chitosan	3.1	6.7	30±2	[129]
Lanthanum incorporated chitosan beads	4.7	5	30±1	[130]
La-incorporated chitosan beads	4.7		30±1	[131]
Lanthanum impregnated chitosan flakes	1.27			[132]
La(III)-incorporated carboxylated chitosan beads	4.711	Neutral pH	30	[133]
Zr(IV) entrapped chitosan polymeric matrix	4.850	Neutral pH	30	[134]
Zr(IV) impregnated dithiocarbonate modified chitosan beads	4.58	7	30	[135]
Aluminum-Impregnated Chitosan Biopolymer	1.73	6.7	25±2	[136]
Alumina/chitosan composite	3.81	Neutral pH	30	[137]

Table 5. Adsorption capacities and other parameters for the removal of fluoride by biosorbents and natural materials modified with metals.

Adsorbent	Fluoride adsorption capacity/ mg g ⁻¹	Optimal pH	Temperature/°C	Reference
Fungal Pleurotus osteatus 1804 SP as biosorbents	1.27	7	30	[138]
cellulose@hydroxyapatite nanocomposites	4.22	6.5	25±1	[139]
Fe(III)-loaded ligand exchange cotton cellulose adsorbent	18.6	5.6	25	[140]
Magnesia-loaded fly ash cenospheres	6.0	3	45	[142]
Zr(IV) loaded dried orange juice residue	13.9	4	rt*	[143]
Sc-Saponified orange juice residue	0.6 (mmol/g)	4	30	[144]
Jm- Saponified orange juice residue	1.22 (mmol/g)	5	30	[144]
La- Saponified orange juice residue	1.06 (mmol/g)	4	30	[144]
Ho- Saponified orange juice residue	0.92(mmol/g)	4	30	[144]
Aluminum hydroxide coated rice husk ash	15	5	27±1	[145]
Carboxylated aerobic granules containing Ce(III)	45.80	Neutral pH	25±1	[146]
Hydrous ferric oxide doped alginate beads b	8.9	7	29	[147]
Lanthanum Alginated Beads	197.2	4	25	[148]
La ³⁺ -impregnated cross- linked gelatin	21.28	5-7	29	[149]

Table 5. Adsorption capacities and other parameters for the removal of fluoride by biosorbents and natural materials modified with metals. (*Continuation*)

*room temperature

Adsorbent	Fluoride adsorption capacity/ mg g ⁻¹	Optimal pH	Temperature/°C	Reference
FeSO ₄ ·7H ₂ O impregnated granular ceramics	2.157	6.9±0.1	30	[20]
Fe ₂ O ₃ impregnated granular ceramics	1.699	6.9±0.1	30	[150]
Zr(IV)-ethylenediamine	37.03	7	25±2	[151]
Zr(IV) surface immobilized	5.52		30	[152]
Activated Cerium(IV) oxide/SiMCM-41	5-6 (mmol/g)		20	[153]
Thorium phosphate composite	4.74	Neutral pH	25±2	[154]
200CT resin loaded with lanthanum	1.34	6	30	[155]
Fe-Al-impregnated granular ceramic adsorbent	3.56	6.9±0.1	25±1	[156]
Fe-Al-CE hydroxide nanoadsorbent-polyvinyl alcahol	4.46	6.5	25	[157]

Table 6. Adsorption capacities and other parameters for the removal of fluoride by modified synthetic resins, ceramics and polymers.

Figure 1. Schematic representation of reverse osmosis.

Figure 2. Schematic representation of electrodialysis.

Acceptico







Highlights

~

- Efforts to reduce fluoride from drinking water to acceptable limits are essential.
- More efficient and cost-effective materials are needed for water defluoridation.
- Adsorption is an important process to remove fluoride from water.
- Metal oxyhydroxides have a high potential for water defluoridation.